

To: Ms. Jennifer Reagan

From: Craig Messinger

Re: Fire Alarm system at 128 Glenwood st.

Dear Madam,

You have chosen to install a monitored Fire Alarm system, through Cunningham alarm company, in Lieu of removing existing doors in your 3 family apartment building and replacing them with Fire rated 1 hour doors. This agreement is what we consider an equivalency to the Life Safety Code and applies to the property located at 128 Glenwood street in Portland Maine. The Alarm was tested on this day, March 25, 2015 and is now in service.


Respectfully,



Craig Messinger,

Portland Fire Prevention

Signature of Property Owner:

 4-16-15