

WINDOW SCHEDULE

MARK	SIZE		Style	NOTES
	WIDTH	HEIGHT		
1	2'-6 1/2"	4'-4"	Double Hung	--
2	8'-0"	5'-6"	Boy	EXISTING
3	6'-0"	5'-6"	Boy	EXISTING
4	2'-6 1/2"	3'-2"	Double Hung	--
5	2'-6 1/2"	4'-4"	Double Hung	EGRESS
6	2'-6 1/2"	4'-4"	Double Hung	--
7	2'-8 1/2"	5'-8"	Double Hung	--
8	2'-8 1/2"	5'-8"	Double Hung	--
9	2'-6 1/2"	2'-8"	Awning	--
10	2'-4"	3'-8"	Cosement	EGRESS
10	2'-6 1/2"	2'-8"	Awning	--
11	2'-4"	3'-8"	Cosement	EGRESS
12	2'-4"	3'-8"	Cosement	EGRESS
13	2'-4"	3'-8"	Cosement	EGRESS
14	2'-6 1/2"	4'-8"	Double Hung	--
15	2'-6 1/2"	4'-8"	Double Hung	--
16	2'-6 1/2"	4'-8"	Cosement	EGRESS
17	2'-6 1/2"	4'-8"	Double Hung	--
18	2'-6 1/2"	4'-8"	Double Hung	--

DOOR AND FRAME SCHEDULE

MARK	DOOR SIZE		GLAZING	FIRE RATING LABEL	NOTES
	WD	HGT			
1	5'-0"	6'-8"	--	--	--
1	6'-0"	7'-0"	TEMPERED	--	Tempered glass sidelites
2	5'-0"	6'-8"	--	--	--
2	5'-0"	6'-8"	--	--	--
3	2'-6"	6'-1"	--	--	--
4	2'-6"	6'-1"	--	--	--
5	2'-6"	6'-1"	--	--	--
6	2'-6"	6'-8"	--	--	--

WINDOW NOTES:
 CONTRACTOR SHALL VERIFY ALL WINDOW OPENINGS AND EGRESS REQUIREMENTS BEFORE ORDERING

ALL WINDOWS SHALL BE LOW E, ARGON FILLED INSULATING GLASS.
 ALL WINDOWS TO HAVE A U-FACTOR RATING OF 0.30 OR BETTER.
 ALL WINDOW GRILLES SHALL BE SIMULATED DIVIDED LITE.

ALL GLAZING SHALL CONFORM TO IRC 2009 R308
 WINDOW GLAZING WITH SILL HTS LESS THAN 18" TO BE TEMPERED.
 WINDOW GLAZING 24" OR CLOSER TO DOORS SHALL BE TEMPERED.
 WINDOW GLAZING 36" OR CLOSER TO STAIRWAYS AND 36" OR LESS ABOVE FLOOR SHALL BE TEMPERED.
 WINDOW GLAZING WITHIN 60" OF THE BOTTOM OF A STAIRWAY AND LESS THAN 36" ABOVE THE FLOOR SHALL BE TEMPERED.

ALL WINDOWS SHALL CONFORM TO R312.2 WINDOW FALL PROTECTION
 ALL WINDOWS WITH SILL HTS LESS THAN 24" AND MORE THAN 72" ABOVE GRADE TO HAVE OPENING LIMITERS TO RESTRICT OPENING TO 4".

R310 EMERGENCY ESCAPE AND RESCUE OPENINGS
 SLEEPING ROOMS SHALL HAVE AT LEAST ONE EGRESS WINDOW WITH A SILL HT OF NOT MORE THAN 44", A MINIMUM CLEAR OPENING HEIGHT OF 24" AND A MINIMUM CLEAR OPENING WIDTH OF 20"

PROSPECT



DESIGN
 58 FORE ST. PORTLAND, ME
 www.prospectdesign.me
 T. 207-749-7400

HEMESphere
 DESIGN

Architecture
 58 Fore Street
 Portland, ME 04101
 joe@hemespheredesign.com
 www.hemespheredesign.com



SCHEDULES & DETAILS

DODGE

DATE: 3.22.2017
 DRAWN BY: BB

A7