



WHIPPLE-CALLENDER ARCHITECTS

MEMORANDUM 4.10.13

DATE: April 10, 2013

TO: City of Portland Fire Dept.
c/o Lt. Ben Wallace
380 Congress St.
Portland, Maine 04101

RE: 145 Glenwood Ave

Clarification request

1. Door 209 to egress stair 209 will be a 20 min. rated door.
2. Partition type 3 is a one hour rated partition, 5/8" sheetrock ea. side, U.L. 359.

Thanks-

Joe Delaney, Reg. Maine Architect
Whipple Callender Architects