



... Fire Protection by Computer Design

DEAN AND ALLYN, INC.
116 LEWISTON ROAD
GRAY MAINE 04039
207 657 5646

Job Name : GLENWOOD KITCHEN
Building : KITCHEN
Location : 145 GLENWOOD AVE. PORTLAND, MAINE
System : ONE
Contract : C131155
Data File : GLENWOOD KITCHEN.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - PLYMOUTH HOUSE Date - 8-15-13
 Location - 145 GLENWOOD AVE. PORTLAND, MAINE
 Building - KITCHEN System No. - ONE
 Contractor - DEAN AND ALLYN, INC. Contract No. - C131155
 Calculated By - H. KING Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height 10'
 OCCUPANCY - APARTMENT HOUSE

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
 Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
 S ()Other
 T ()Specific Ruling Made by Date
 E
 M Listed Flow at Start Point - 13 Gpm System Type
 Listed Pres. at Start Point - 9.1 Psi (X) Wet () Dry
 D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
 E Domestic Flow Added - Gpm Sprinkler or Nozzle
 S Additional Flow Added - Gpm Make RELIABLE Model RFC43
 I Elevation at Highest Outlet - 10' Feet Size 1/2" K-Factor 4.3
 G Note:CUSHION 22.5 PSI Temperature Rating 165
 N

Calculation Gpm Required 59.2 Psi Required 48.4 CITY
 Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - Rated Cap. Cap.
 T Time of Test - @ Psi Elev.
 E Static (Psi) - 71 Elev.
 R Residual (Psi) - 64 Other Well
 Flow (Gpm) - 992 Proof Flow Gpm
 S Elevation - 0

P Location: GLENWOOD AVE
 P
 L Source of Information: PORTLAND WATER DIST 2008
 Y

Final Calculations - Standard

DEAN AND ALLYN, INC.
GLENWOOD KITCHEN

Page 2
Date 8-15-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1A to 1	12.96	1.049 120 0.0584	1E 2.0 1T 5.0 0.0	1.000 7.000 8.000	7.000 7.363 0.467		K Factor = 4.90		
	0.0 12.96					14.830	K Factor = 3.37		
5 to 59	12.97	1.049 120 0.0584	5E 10.0 0.0 0.0	12.000 10.000 22.000	9.100 0.0 1.285		K Factor = 4.30		
	0.0 12.97					10.385	K Factor = 4.02		
6 to 59	13.08	1.049 120 0.0594	3E 6.0 1T 5.0 0.0	8.000 11.000 19.000	9.257 0.0 1.128		K Factor = 4.30		
	0.0 13.08					10.385	K Factor = 4.06		
7 to 60	39.98	1.049 120 0.4687	5E 10.0 0.0 0.0	16.200 10.000 26.200	10.491 0.0 12.281		K Factor = 4.30		
	0.0 39.98					22.772	K Factor = 8.38		
8 to 60	19.17	1.049 120 0.1203	1E 2.0 1T 5.0 0.0	17.000 7.000 24.000	19.884 0.0 2.888		K Factor = 4.30		
	0.0 19.17					22.772	K Factor = 4.02		
59 to 7	26.05	1.049 120 0.2120	0.0 0.0 0.0	0.500 0.0 0.500	10.385 0.0 0.106			Vel = 9.67	
	0.0 26.05					10.491	K Factor = 8.04		
60 to 61	59.16	1.38 120 0.2545	1E 3.0 0.0 0.0	11.000 3.000 14.000	22.772 0.0 3.563			Vel = 12.69	
61 to 62	0.0	1.38 120 0.2545	1E 3.0 0.0 0.0	10.600 3.000 13.600	26.335 4.331 3.461			Vel = 12.69	
62 to 63	0.0	1.61 120 0.1201	1E 4.0 1T 8.0 0.0	11.000 12.000 23.000	34.127 0.0 2.763			Vel = 9.32	
63 to TR	0.0	1.61 120 0.1201	1E 4.0 1T 8.0 0.0	54.700 12.000 66.700	36.890 0.0 8.012			Vel = 9.32	

Final Calculations - Standard

DEAN AND ALLYN, INC.
GLENWOOD KITCHEN

Page 3
Date 8-15-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
TR	0.0	2.067	1Z 5.0	7.000	44.902		
to		120	0.0	5.000	3.000		* Fixed loss = 3.000
FF	59.16	0.0355	0.0	12.000	0.426		Vel = 5.66
FF	0.0	4.1	2E 29.067	50.000	48.328		
to		140	1T 29.067	61.041	0.0		
CTY	59.16	0.0010	1G 2.907	111.041	0.106		Vel = 1.44
	0.0						
	59.16				48.434		K Factor = 8.50

Fittings Used Summary

DEAN AND ALLYN, INC.
GLENWOOD KITCHEN

Page 4
Date 8-15-13

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

DEAN AND ALLYN, INC.
 GLENWOOD KITCHEN

Page 5
 Date 8-15-13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1A	17.0	4.9	7.0	na	12.96	.05	256	7.0
5	10.0	4.3	9.1	na	12.97	.05	256	9.1
6	10.0	4.3	9.26	na	13.08	.05	256	9.1
7	10.0	4.3	10.49	na	13.93	.05	256	9.1
8	10.0	4.3	19.88	na	19.17	.05	256	9.1
59	10.0		10.39	na				
60	10.0		22.77	na				
61	10.0		26.33	na				
62	0.0		34.13	na				
63	0.0		36.89	na				
TR	0.0		44.9	na				
FF	0.0		48.33	na				
CTY	0.0		48.43	na				

The maximum velocity is 14.84 and it occurs in the pipe between nodes 7 and 60

Water Supply Curve (C)

DEAN AND ALLYN, INC.
GLENWOOD KITCHEN

Page 6
Date 8-15-13

City Water Supply:

C1 - Static Pressure : 71
C2 - Residual Pressure: 64
C2 - Residual Flow : 992

