



... Fire Protection by Computer Design

DEAN AND ALLYN, INC.  
116 LEWISTON ROAD  
GRAY MAINE 04039  
207 657 5646

Job Name : GLENWOOD COMMON ROOM  
Building : COMMON ROOM  
Location : 145 GLENWOOD AVE. PORTLAND, MAINE  
System : ONE  
Contract : C131155  
Data File : GLENWOOD COMMON ROOM.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - PLYMOUTH HOUSE Date - 8-15-13  
 Location - 145 GLENWOOD AVE. PORTLAND, MAINE  
 Building - COMMON ROOM System No. - ONE  
 Contractor - DEAN AND ALLYN, INC. Contract No. - C131155  
 Calculated By - H. KING Drawing No. - 1 OF 1  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 10'  
 OCCUPANCY - APARTMENT HOUSE

S Type of Calculation: ( )NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
 Y Number of Sprinklers Flowing: ( )1 ( )2 (X)4 ( )  
 S ( )Other  
 T ( )Specific Ruling Made by Date  
 E  
 M Listed Flow at Start Point - 13 Gpm System Type  
 Listed Pres. at Start Point - 9.1 Psi (X) Wet ( ) Dry  
 D MAXIMUM LISTED SPACING 14 x 14 ( ) Deluge ( ) PreAction  
 E Domestic Flow Added - Gpm Sprinkler or Nozzle  
 S Additional Flow Added - Gpm Make RELIABLE Model RFC43  
 I Elevation at Highest Outlet - 20.5'Feet Size 1/2" K-Factor 4.3  
 G Note:CUSHION 16.8 PSI Temperature Rating 165  
 N

Calculation Gpm Required 40.9 Psi Required 54.2 CITY  
 Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:  
 A Date of Test - Rated Cap. Cap.  
 T Time of Test - @ Psi Elev.  
 E Static (Psi) - 71 Elev.  
 R Residual (Psi) - 64 Other Well  
 Flow (Gpm) - 992 Proof Flow Gpm  
 S Elevation - 0

P Location: GLENWOOD AVE  
 P  
 L Source of Information: PORTLAND WATER DIST 2008  
 Y

Final Calculations - Standard

DEAN AND ALLYN, INC.  
 GLENWOOD COMMON ROOM

Page 2  
 Date 8-15-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
1A to 1	12.96	1.049 120 0.0584	1E 2.0 1T 5.0 0.0	1.000 7.000 8.000	7.000 7.363 0.467		K Factor = 4.90 Vel = 4.81
	0.0 12.96					14.830	K Factor = 3.37
9 to 10	13.70	1.049 120 0.0646	1E 2.0 0.0	10.700 2.000	10.144 0.0		K Factor = 4.30 Vel = 5.09
10 to 64	14.23	1.049 120 0.2414	1T 5.0 0.0 0.0	4.700 5.000 9.700	10.964 0.0 2.342		K Factor = 4.30 Vel = 10.37
	0.0 27.93					13.306	K Factor = 7.66
11 to 64	12.97	1.049 120 0.0584	4E 8.0 2T 10.0 0.0	54.000 18.000 72.000	9.100 0.0 4.206		K Factor = 4.30 Vel = 4.81
64 to 65	27.93	1.049 120 0.4888	1E 2.0 0.0	0.500 2.000	13.306 0.0		Vel = 15.18
65 to 66	0.0	1.049 120 0.4889	1E 2.0 0.0	10.500 2.000	14.528 4.548		Vel = 15.18
66 to 60	0.0	1.049 120 0.4890	1E 2.0 1T 5.0 0.0	18.300 7.000 25.300	25.187 0.0 12.371		Vel = 15.18
60 to 61	0.0	1.38 120 0.1286	1E 3.0 0.0	10.800 3.000	37.558 0.0		Vel = 8.77
61 to 62	0.0	1.38 120 0.1286	1E 3.0 0.0	10.700 3.000 13.700	39.332 4.331 1.762		Vel = 8.77
62 to 63	0.0	1.61 120 0.0607	1T 8.0 1E 4.0 0.0	11.000 12.000 23.000	45.425 0.0 1.396		Vel = 6.45
63 to TR	0.0	1.61 120 0.0607	1E 4.0 1T 8.0 0.0	54.800 12.000 66.800	46.821 0.0 4.055		Vel = 6.45
TR to FF	0.0	2.067 120 0.0179	1Z 5.0 0.0	7.000 5.000	50.876 3.000		* Fixed loss = 3.000 Vel = 3.91
FF to CTY	0.0	4.1 120 0.0006	2E 21.855 1T 21.855 1G 2.186	50.000 45.896 95.896	54.091 0.0 0.062		Vel = 0.99

Final Calculations - Standard

DEAN AND ALLYN, INC.  
 GLENWOOD COMMON ROOM

Page 3  
 Date 8-15-13

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 40.90				54.153			K Factor =	5.56

# Fittings Used Summary

DEAN AND ALLYN, INC.  
GLENWOOD COMMON ROOM

Page 4  
Date 8-15-13

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

DEAN AND ALLYN, INC.  
 GLENWOOD COMMON ROOM

Page 5  
 Date 8-15-13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1A	17.0	4.9	7.0	na	12.96	.05	256	7.0
9	20.5	4.3	10.14	na	13.7	.06	196	9.1
10	20.5	4.3	10.96	na	14.24	.06	196	9.1
11	20.5	4.3	9.1	na	12.97	.06	196	9.1
64	20.5		13.31	na				
65	20.5		14.53	na				
66	10.0		25.19	na				
60	10.0		37.56	na				
61	10.0		39.33	na				
62	0.0		45.42	na				
63	0.0		46.82	na				
TR	0.0		50.88	na				
FF	0.0		54.09	na				
CTY	0.0		54.15	na				

The maximum velocity is 15.18 and it occurs in the pipe between nodes 64 and 65

# Water Supply Curve (C)

DEAN AND ALLYN, INC.  
 GLENWOOD COMMON ROOM

Page 6  
 Date 8-15-13

City Water Supply:  
 C1 - Static Pressure : 71  
 C2 - Residual Pressure: 64  
 C2 - Residual Flow : 992

