

Legalization Inspection Form

Date: 10/11/17

Address: 120 Concord Street

Legal Use: Two family

Proposed Use: Three family including the detached garage

Common Areas \_\_\_\_\_

**Basement**

- Fire Door: \_\_\_\_\_
- Detection: \_\_\_\_\_
- Sprinkler Head: \_\_\_\_\_
- Electrical/panel: \_\_\_\_\_

Notes: \_\_\_\_\_

**Unit 3**

- Fire Door: \_\_\_\_\_
- Detection: Smoke and Carbon monoxide detectors need to be hard wired
- Egress: \_\_\_\_\_

Notes: The garage which is below the living space needs to be fire rated separation

**Unit \_\_\_\_\_**

- Fire Door: \_\_\_\_\_
- Detection: \_\_\_\_\_
- Egress: \_\_\_\_\_

Notes: \_\_\_\_\_