Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/22/18

# Legalization Inspection Form

Date: 10/11/17

Address: 120 Concord Street

Legal Use: Two family

Proposed Use: Three family including the detached garage

***Common Areas*** _____

***Basement***

- Fire Door: _____
- Detection: _____
- Sprinkler Head: _____
- Electrical/panel: _____

Notes: _____

***Unit*** 3

- Fire Door: _____
- Detection: Smoke and Carbon monoxide detectors need to be hard wired
- Egress: _____

Notes: The garage which is below the living space needs to be fire rated separation

***Unit*** ___

- Fire Door: _____
- Detection: _____
- Egress: _____

Notes: _____