

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

LARSSON ERIC M & JEAN A TALBOT JTS

Located at

65 BERKELEY ST

PERMIT ID: 2015-01803

ISSUE DATE: 10/08/2015

CBL: 131 J001001

has permission to **Change of use from one to two family - demolish the existing, single story section & add a1,380 sf additon with a new dwelling unit.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final - DRC

Site VISIT

Setbacks and Footings Prior to Pouring

Foundation/Backfill

Electrical Close-in

Close-in Plumbing/Framing

Certificate of Occupancy/Final

Final - Fire

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01803	Date Applied For: 07/28/2015	CBL: 131 J001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Two-(2-) Family Home		Proposed Project Description: Change of use from one to two family - demolish the existing, single story section & add a 1,380 sf addition with a new dwelling unit.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 09/28/2015
Note: The bulkhead has been relocated from the rear (east side) of the addition to the left (north side) of the addition on the newest plans (9/23/15). The elevation plans show the incorrect location on the rear (east side) of the addition .		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Per the Fire Department, the new unit requires a sprinkler system.				
2) This property shall remain a two family dwelling. Any change of use shall require a separate permit application for review and approval.				
Dept: DRC		Status: Approved w/Conditions	Reviewer: Philip DiPierro	Approval Date: 10/08/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) The site shall be developed and maintained as depicted in the approved site plan, written submission of the applicant, and these written conditions of approval. The modification of the approved site plan or alteration of a parcel which was the subject of site plan approval shall require the prior approval of a revised site plan by the Planning Authority.				
2) A performance guarantee will be required to cover the cost of site work not completed due to seasonal conditions ie., finish grading, loaming, seeding, mulching, installation of street trees, etc. The performance guarantee must be reviewed, approved, and accepted by the Planning Authority prior to the release of a Temporary Certificate of Occupancy.				
3) This site must comply with the Landscape Preservation Standards outlined in the Land Use Ordinance, section 14-526(b)2a, stating that a minimum of 30% of existing trees, ten (10) inches DBH or greater, within the required setback, must be preserved. Trees that are designated to be saved are to be protected during excavation and construction. Tree protection fencing is to be installed around the tree canopy drip line prior to the start of any excavation. Tree protection measures are to be inspected and maintained daily.				
4) The applicant shall have a licensed surveyor install, prior to the issuance of any Certificate of Occupancy, permanent monumentation/pins identifying property corners.				
5) Erosion and Sedimentation control shall be established and inspected by the Development Review Coordinator prior to soil disturbance, and shall be done in accordance with Best Management Practices, Maine Department of Environmental Protection Technical and Design Standards and Guidelines. All Erosion and Sedimentation control measures must be inspected and maintained daily.				
6) The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions.				
7) All Site work (final grading, landscaping, loam and seed) must be completed prior to issuance of a certificate of occupancy.				
8) A street opening permit(s) may be required for your site. Please contact Carol Merritt at 874-8300, ext. 8822. (Only excavators licensed by the City of Portland are eligible.)				
9) A sewer permit may be required for your project. Please contact Carol Merritt at 874-8300, ext. 8822. The Wastewater and Drainage section of Public Services must be notified five (5) working days prior to sewer connection to schedule an inspector for your site.				
10) All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a certificate of occupancy.				
11) The Development Review Coordinator (874-8632) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind.				