RESURGAM. MAINE. AND. CITY OF PORTLAND
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/15/16

Typical wall Section

2X4X10' wall wood const with the exception of 1 wet wall which will Be min. 2X6

2X6 DROpped cieling with 1X4 Strapping

1/2 DRYwall thru out
mold resistant DRY wall
In Bathroom

5/8 DRY wall where Interior wall is inside of Hall. way that FireRated