SELECTOR SWITCH

PILOT LIGHT

TEMPERATURE SWITCH

FIRE ALARM SYMBOLS F PULL STATION

▼xx FIRE ALARM AUDIBLE/VISIBLE H NOTIFICATION APPLIANCE (GENERAL EVACUATION) STROBE UNIT XX= CANDELA

FIXED TEMP HEAT DETECTOR (135F OR 200F)

FIRE ALARM CONTROL PANEL

DIGITAL COMMUNICATOR

SD DUCT SMOKE DETECTOR

T REMOTE TEST STATION

H MINI HORN UNIT S SMOKE DETECTOR

TS SPRINKLER TAMPER SWITCH

FS SPRINKLER FLOW SWITCH PS SPRINKLER PRESSURE SWITCH

ANNUNCIATOR

MB MASTER BOX

MM MONITOR MODULE

CM CONTROL MODULE

\$_120 NON-SYSTEM SMOKE DETECTOR STR = DENOTES INTEGRAL STROBE FOR H/C UNITS

(L) RED MASTER BOX LIGHT

KB KNOX BOX, FBO

DH DOOR HOLDER

EXT HOOD EXT SYSTEM

FCPS SIGNAL POWER EXTENDER RADIO SYSTEM TRANSMITTER

SYSTEMS SYMBOLS

TELEPHONE SYSTEM WALL JACK

COMBINATION VOICE/DATA SYSTEM OUTLET COMBINATION VOICE/DATA SYSTEM OUTLET

IN FLOOR BOX. FURNISH 1" CONDUIT IN SLAB

TV CATV JACK

SECURITY SYSTEM DOOR SWITCH

ELECTRIC DOOR LOCK SET

SECURITY SYSTEM CARD ACCESS PAD

INTERCOM SYSTEM SPEAKER

INT INTERCOM MASTER STATION

---- CABLE TRAY

PUSH BUTTON

DB DOOR BELL

GENERAL NOTES

1. ALL WORK SHALL BE IN COMPLIANCE WITH NFPA-70, NATIONAL ELECTRICAL CODE.

2. ALL MOTOR SAFETY SWITCHES, DISCONNECTS AND MOTOR STARTERS ARE FURNISHED BY DIVISION 16000 UNLESS NOTED AS FURNISHED WITH EQUIPMENT (FWE).

3. UNLESS OTHERWISE NOTED, CONVENIENCE RECEPTACLES SHALL BE MOUNTED 18 INCHES AFF AND LIGHTING TOGGLE SWITCHES 48 INCHES AFF.

4. ALL PENETRATIONS THROUGH FLOORS, RATED WALLS AND PARTITIONS SHALL BE SEALED WITH A UL APPROVED FIRE SEALANT METERIAL TO MAINTAIN THE RATING OF THE SEPARATION.

5. LIGHTING TOGGLE SWITCHES SHALL BE COMMERCIAL SPECIFICATION GRADE, 120 VOLT, SIDE WIRED AS MANUFACTURED BY LEVITON, PASS & SEYMOUR, OR APPROVED EQUAL.

6. CONVENIENCE RECEPTACLES SHALL BE COMMERCIAL SPECIFICATION GRADE UNLESS SHOWN OTHERWISE, GROUNDING TYPE, NEMA 5-20R, SIDE WIRED, AS MANUFACTURED BY LEVITON, PASS & SEYMOUR, OR APPROVED EQUAL.

7. DEVICE COVERPLATES SHALL BE THERMOPLASTIC NYLON TYPE WITH IVORY FINISH IN ALL FINISHED SPACES. MECHANICAL ROOMS, ELECTRICAL ROOM, AND UTILITY ROOMS SHALL BE FURNISHED WITH BRUSHED STAINLESS STEEL COVERPLATES.

8. UNLESS OTHERWISE NOTED ALL HOMERUNS FOR 15 OR 20A CIRCUITS SHALL BE 2#12AWG & #12 GND. HOMERUNS FED FROM 20A, 1P CIRCUITS IN EXCESS OF 100 FEET (FOR 120V CIRCUITS) SHALL BE #10AWG. ALL WIRING SHALL BE COPPER.

9. CONDUIT SYSTEMS: EXPOSED INTERIOR CONDUITS SHALL BE EMT, 3/4" MINIMUM. PROPERLY SUPPORTED MC AND NM CABLE ASSEMBLIES MAY BE USED WHERE CONCEALED ABOVE CEILINGS AND IN WALLS. FLEXIBLE LIQUIDTIGHT CONDUIT WHIPS SHALL BE USED FOR CONNECTION TO VIBRATING EQUIPMENT IN THE MECHANICAL ROOM.

ABBREVIATIONS

 KW

KWH

LPS

LTG

LSW

KILOWATT

LIGHTING

LIGHT SWITCH

KILOWATT HOUR

LOW PRESSURE SODIUM

LOW VOLTAGE AMPERE MCB MAIN CIRCUIT BREAKER ALTERNATING CURRENT MOTOR CONTROL CENTER ABOVE FINISHED FLOOR MOTOR CIRCUIT PROTECTION AFG ABOVE FINISHED GRADE AIC AMPERES INTERRUPTING CAPACITY METAL HALIDE EMH ELECTRICAL MANHOLE ALUMINUM MAIN LUGS ONLY ASYMMETRICAL MECHANICALLY OPERATED ATS AUTOMATIC TRANSFER SWITCH AUX MOTOR OPERATED DAMPER AUXILIARY AWG MANUAL TRANSFER SWITCH AMERICAN WIRE GAUGE BKR MERCURY VAPOR **BREAKER** MEGAVOLT-AMPERE **CONDUIT** CAB CABINET NORMALLY CLOSED NORMALLY OPENED CB CIRCUIT BREAKER CKT OVERHEAD CIRCUIT CT OVER LOAD CURRENT TRANSFORMER OOA CU ON-OFF-AUTOMATIC COPPER OUTSIDE STEM & YOKE VALVE (FA SYSTEM) DIRECT CURRENT DISC DISCONNECT PUSH BUTTON EQUIPMENT GROUND POWER FACTOR ELECTRICALLY HELD PHASE **EMERGENCY** ELECTRICAL METALLIC TUBING PANEL EΟ PRIMARY ELECTRICALLY OPERATED EPR ETHYLENE PROPYLENE RUBBER POTENTIAL TRANSFORMER PVC EQUIP POLYVINYL CHLORIDE **EQUIPMENT** RIGID GALVANIZED STEEL CONDUIT ΕX EXTERIOR **RVSS** FΑ REDUCED VOLTAGE SOLID STATE FIRE ALARM RSC FC RIGID STEEL CONDUIT FOOT-CANDLE FDR RVAT REDUCED VOLTAGE AUTO TRANSFORMER FEEDER **FLUOR** FLUORESCENT FLOW SWITCH (FA SYSTEM) SEC FS SECONDARY SHLD FULL VOLTAGE NON REVERSING SHIELDED CABLE FVR SW SWITCH FULL VOLTAGE REVERSING SWBD GEN SWITCHBOARD GENERATOR GF SYM SYMMETRICAL GROUND FAULT GFI GROUND FAULT CIRCUIT INTERRUPTER TELEPHONE GND TRANSFORMER GROUND TO BE DETERMINED HAND HOLE HOA TELEDIALER HAND-OFF-AUTOMATIC TDR HP HORSE POWER TIME DELAY RELAY HIGH PRESSURE SODIUM TELEPHONE TELEMETRY HIGH VOLTAGE HΖ HERTZ UNDERGROUND UTILITY ISOLATED GROUND IMC INTERMEDIATE METAL CONDUIT VOLT INCAND INCANDESCENT VOLT-AMPERE JB JUNCTION BOX VARIABLE FREQUENCY DRIVE **KCMIL** THOUSAND CIRCULAR MILS ΚV WATT HOUR KILOVOLT KVA WEATHERPROOF KILO VOLT-AMPERE

TRANSFORMER

EXPLOSION PROOF

CROSS LINKED POLYETHYLENE

XFMR

XLP

SWIFTCURRENT Engineering Services 10 Forest Falls Dr. Unit 4b Yarmouth, ME 04096 Tel: (207) 847-9280 PLAN NUMBER GRAPHIC SCALE

THEOTHY D.

AND PUBLIC LIBR URBANK BRANCH

 \circ

PERMITTING

ISSUED

041 Stevens Aving Center land, Maine POR $M \cap M$

MAINE n for ibrary ORTLAND, N + Renovation ank Branch Libi \Box OF ditic Bur

 $\overline{\Box}$

ELECTRICAL LEGEND, SYMBOLS, & NOTES

SHEET # **E0.0**