


NOTES:

1. SEE EO.O FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES.

KEYED NOTES:

- (1) EXISTING LIGHTING TO REMAIN IN 103 TOILET AND 104 STAIR.
- $\overline{2}$ EXISTING WALL LIGHTING FIXTURES TO REMAIN IN 111 YOUTH SERVICES.
- $\overline{3}$ REMOVE EXISTING HORN STROBE. REINSTALL HORN STROBE AS SHOWN.
- RELOCATE SMOKE DETECTOR IN THIS ROOM TO ACCOMMODATE NEW OFFICE WALLS AND PROVIDE COVERAGE OF NEW PROCESSING ROOM,



PORTLAND PUBLIC LIBRARY BURBANK BRANCH

377 Stevens Avenue Deering Center Portland, Maine 04103

MAINE n for ibrary BIDDING PORTLAND, on + Renovation rbank Branch Lik ISSUED CITY OF Addition The Burk

ELECTRICAL LIGHTING & FIRE ALARM PLAN - FIRST

SHEET # **E2.1** PLAN NUMBER

SWIFTCURRENT Engineering Services 10 Forest Falls Dr. Unit 4b Yarmouth, ME 04096 Tel: (207) 847—9280 GRAPHIC SCALE