DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

CITY OF PORTLAND

Located at

377 STEVENS AVE

PERMIT ID: 2015-00303

ISSUE DATE: 11/24/2015

132 E001001 CBL:

has permission to Interior renovations, mechanical upgrades, window replacements, and elevator installation for the Portland Public Library - Burbank Branch.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

Type: 5A

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

Public Library

Use Group: A-3

Assembly - Public Library

No sprinkler

ENTIRE

MUBEC/IBC 2009

Located at: 377 STEVENS AVE **PERMIT ID:** 2015-00303 CBL: 132 E001001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Foundation/Backfill

Close-in Plumbing/Framing w/Fire & Draft Stopping

Above Ceiling Inspection

Electrical Close-in w/Fire & Draftstopping

Final - Electric

Final - Fire

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 8	74-8716	2015-00303	02/23/2015	132 E001001
Proposed Use: Same: Library (Assembly) - Portland Public Library - Burbank Branch	Interior	vator installation fo	nanical upgrades, win	
Dept: Zoning Status: Approved R Note: Conditions:	eviewer:	Tammy Munson	Approval Da	te: 03/11/2015 Ok to Issue: ✓
Dept: Building Inspecti Status: Approved w/Conditions R Note:	eviewer:	Laurie Leader	Approval Da	te: 11/20/2015 Ok to Issue: ✓
 Conditions: Separate permits are required for any electrical, plumbing, sprink pellet/wood stoves, commercial hood exhaust systems, fire supprapproval as a part of this process. A final report of special inspections is required stating conformat Special Inspections. This shall include a sealed letter from the S 	ression and	I fuel tanks. Separ	ate plans may need to	be submitted for d Statement of
issuance of a certificate of occupancy. This report shall documents 3) This permit is approved based upon information provided by the approved plans requires separate review and approval prior to we	applicant	•		
Dept: Engineering DPS Status: Not Applicable R	eviewer:		Approval Da	te: 03/05/2015
Note:				Ok to Issue: 🔽
 Conditions: This approval is non-applicable to Engineering DPS as it relates Grease Program. If approval is needed for this project by the Eng FOG, please contact David Margolis-Pineo at 207-874-8850 or contact Dept: Fire Status: Approved w/Conditions R 	gineering I lmp@port	Department of Pub		other reason than
Notes		<i>c c</i>		Ok to Issue:

Conditions:

- 1) All outstanding code violations shall be corrected prior to final inspection.
- 2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 3) Assembly and educational occupancies and uses with an occupant load of 100 or more persons required listed panic or fire exit hardware on doors serviing as a means of egress.
- 4) Shall comply with NFPA 101, Chapter 13, Existing Assembly Occupancies.
- 5) Shall meet the requirements of 2009 NFPA 1 Fire Code.
- 6) All construction shall comply with City Code Chapter 10.