


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

July 10, 2017

ANDREA LARSEN
 40 LELAND ST
 PORTLAND ME 04103

Location 40 LELAND ST	CBL 133 C010001	Inspection Date 6/14/2017
Inspector Paul Marshall	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 7/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101- 16.5.2.2 UNVENTED FUEL-FIRED HEATER; Unvented fuel-fired heating equipment, other than gas space heaters in compliance with NFPA 54, shall be prohibited. Boiler properly vented but found to have hole in exhaust pipe. AC Gautreau: Spoke with Andrea on the phone and she will be forwarding a letter from her furnace technician in regards to the vent pipe. She will be addressing it the Capt. Petruccelli. <i>2-mailed letter 7/11/17</i>	<i>7/11/2017</i>
FINAL DATE OF COMPLETED VIOLATION(S)	<i>7/11/2017</i>
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	<i>NA</i> _ / _ / _

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.


VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

7/14/17
Date



Responsible Party

Date

Responsible Party

SEEN AND AGREED

07/17/2017
Date

CAPT.  17
Fire Prevention Bureau