

Fire Dept Headquarter 40 Leland St
380 Congress St Portland, ME
Portland, ME 04101 04103
July 11, 2017

To: Captain Petrucci


I Spoke with Keith Gantreau
on 7/10/17, as a follow-up
to my apartment building
inspection, after having
my Burners serviced and
speaking with them.

Keith asked to have my
Burner Service write a letter
for my file so my inspection
can be closed.

Please see his letter enclosed.

Thank you,

Andren Larsen
Andren Larsen



A.B. Burner Tune-Ups & Service

11 Aspen Lane
Windham, Maine 04062
653-6213

CUSTOMER ORDER NO.						DATE	
						7/11/2017	
NAME							
Andrea Larsen							
ADDRESS							
40 Leland St							
CITY, STATE, ZIP							
Portland							
SALESPERSON		CASH	COD	CHARGE	ON ACCT.	MDS.	RETURN
QTY	DESCRIPTION			PRICE	AMOUNT		
	While TUNEING UP						
	Three Boilers for						
	the customer at						
	40 Leland St Andrea						
	was informed that						
	the smoke pipe has three						
	wholes - in them that						
	needed to be fixed.						
	Those wholes are for						
	efficiency test after						
	Boilers are then						
	cleaned						
				Parts \$			
				Labor			
				Tax			
				Total			
And questions call AB. Burner.							