

Legalization Inspection Form

Date: 8/7/17

Address: 249 Concord St West

Legal Use: TWO Family with unapproved third dwelling Unit.

Proposed Use: Three Family

Common Areas _____

Basement

- Fire Door: _____
- Detection: _____
- Sprinkler Head: _____
- Electrical/panel: _____

Notes: _____

Unit 3

- Fire Door: 2/60 minute Fire door Self Closing Hinges
- Detection: Hardwire Smoke in Bedroom Co Combo in Hallway.
- Egress: yes

Notes: Bathroom Toilet is 6'4" Head Room.

4 - meters 3 units one House.

Unit 2

- Fire Door: 60 minute Self Closing Fire doors
- Detection: _____
- Egress: _____

Notes: _____

Unit 1

- Fire Door: 60 Minute Self Closing Fire Doors
- Detection: _____
- Egress: _____

Notes: _____

Unit ____

- Fire Door: _____
- Detection: _____
- Egress: _____

Notes: _____

Unit ____

- Fire Door: _____
- Detection: _____
- Egress: _____

Notes: _____

Unit ____

- Fire Door: _____
- Detection: _____
- Egress: _____

Notes: _____

Overall Pass _____ Fail _____ Follow up Required

Inspector: Quane Hanson

Fire Prevention: CAPT. J. B. [Signature]