

City of Portland Mail



Keri Ouellette <kouellette@portlandmaine.gov>

53 Leland Street #2017-01921

Tom Gagne <tgagne@cornerstonebr.com>
To: Keri Ouellette <kouellette@portlandmaine.gov>
Cc: ecjo74@yahoo.com

Fri, Dec 15, 2017 at 11:10 AM

Hi Keri, I can confirm that the guard rails will be at least 36 inches from top of decking to top of rail. Thanks for helping this along!

[Quoted text hidden]

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

--

Tom Gagne
Project Manager
CornerStone Building and Restoration
(207) 712-8850
www.cornerstonebr.com