| Protection 1 Branch 11660 | System Outputs | | | |
|---|---|---|---|---|
| 10 Manual Drive, Portland, ME 04103 PH# 1-800-310-5011 | Control Unit Annunciation | Notification | Safety Control | |

System Inputs

| | Actuate common alarm signal indicator | Actuate audible alarm system | Actuate common supervisory signal indicator | Actuate audible supervisory signal | Actuate common trouble signal indicator | Actuate Basment floor evacuation signals | Actuate 1st Floor Evacuation Signals | Actuate 2nd Floor Evacuation Signal | Actuate 3rd Floor Evacuation Signals | Actuate 4th Floor Evacuation Signals | Actuate 5th Floor Evacuation Signals | Transmit fire alarm signal to supervising station | Transmit supervisory signal to supervising | Transmit trouble signal to supervising station |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| System Pull Stations | X | X | | | | X | X | | | | | X | | |
| System Smoke Detectors | X | X | | | | X | X | | | | | X | | |
| System Heat Detectors | X | X | | | | X | X | | | | | X | | |
| Sprinkler Water Flow | | | | | | | | | | | | | | |
| Sprinkler Gate Valve Tamper | | | | | | | | | | | | | | |
| Sprinkler Air Pressure | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| FACP AC Loss | | | X | X | | | | | | | | | X | |
| FACP Low Battery | | | X | X | | | | | | | | | X | |
| FACP Ground Fault | | | X | X | | | | | | | | | X | |
| Phone Line #1 Fail | | | X | X | | | | | | | | | X | |
| Phone Line #2 Fail | | | X | X | | | | | | | | | X | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| Evergreen Cemetery | | | | | | | | | | | | | | |
| 672 Stevens Ave | | | | | | | | | | | | | | |