

135-E-007

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 522 Stevens Ave.		Owner: City of Portland		Phone:		Permit No. 941355 PERMIT ISSUED Permit Issued: DEC 16 1994 CITY OF PORTLAND Zone: R-5 CBL: 135-E-007 Zoning Approval: 12/15/94 Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/> Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Date: 12/15/94 Mr. Carroll		
Owner Address: 389 Congress St.		Leasee/Buyer's Name:		Phone: 874-8300			Business Name:	
Contractor Name: Hainges		Address: P. O. Box 1090 766 Roosevelt Tr Windham, ME 04062		Phone: 244-6713			COST OF WORK: \$ 35.00	
Past Use: School		Proposed Use: School		PERMIT FEE: \$ 35.00			INSPECTION: Use Group: / Type: Signature: [Signature]	
Proposed Project Description: to install propane tank 1000 gal. TEMPORARY submitted plan				PEDESTRIAN ACTIVITIES DISTRICT (P.U.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/> Signature: [Signature] Date: [Date]				
Permit Taken By: LATINO		Date Applied For: 12/14/94						

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

12/14/94

SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

PERMIT ISSUED WITH REQUIREMENTS

4

CEO DISTRICT

Mr. Carroll

BUILDING PERMIT REPORT

DATE: 12/14/54

ADDRESS: 522 Stevens Ave

REASON FOR PERMIT: Install 1-1000 gal ABOVE GROUND L/P TANKS

BUILDING OWNER: City of Portland

CONTRACTOR: Maignas


PERMIT APPLICANT —

APPROVED: DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All above ground L/P storage tanks shall be located in accordance with NFPA #58 standards.
- 2.) Any tank located near the path of vehicle movement shall be protected with appropriate permanent barricades.
- 3.) All piping shall be protected from possible mechanical damage and vandalism.

Lincoln Middle School
522 Stevens Ave.
Portland, Me.
General contractor - Barletta Engineering



1000 gallon propane tank
provided by Maingas.

STEVENS AVE.