



. . . Fire Protection by Computer Design

ACCENDO FIRE PROTECTION LLC
38 ADDITON RD
GREENE, MAINE 04236
207-946-6182

Job Name : 502 DEERING CENTER 3RD FLOOR
Drawing : WOOD FRAMED
Location : PORTLAND, MAINE
Remote Area : WET
Contract : 17-1010
Data File : 17-1019 205 DEERING 3RD FLOOR.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 502 DEERING CENTER Date - 7/10/17
Location - PORTLAND, MAINE
Building - WOOD FRAMED System No. - WET
Contractor - AFP Contract No. - 17-1010
Calculated By - JWD Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-8"
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 17 Gpm System Type
Listed Pres. at Start Point - 12 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 18 x 18 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make VICTAULIC Model VK2730
I Elevation at Highest Outlet - 130.5Feet Size 1/2" K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 69.1 Psi Required 53.7 At NODE BASE
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 7/6/17 Rated Cap. Cap.
T Time of Test - 6:30 AM @ Psi Elev.
E Static (Psi) - 61 Elev.
R Residual (Psi) - 60 Other Well
Flow (Gpm) - 1061 Proof Flow Gpm
S Elevation - 100

P Location: TEST HYDRANT LOCATED ON CORNER OF HARTLEY
P AND STEVENS AVE
L Source of Information:
Y PORTLAND WATER DISTRICT


Water Supply Curve C

ACCENDO FIRE PROTECTION LLC
502 DEERING CENTER 3RD FLOOR

Page 2
Date

City Water Supply:
C1 - Static Pressure : 61
C2 - Residual Pressure: 60
C2 - Residual Flow : 1061

Demand:
D1 - Elevation : 13.210
D2 - System Flow : 69.126
D2 - System Pressure : 54.303
Hose (Demand) : _____
D3 - System Demand : 69.126
Safety Margin : 6.690



Fittings Used Summary

ACCENDO FIRE PROTECTION LLC
502 DEERING CENTER 3RD FLOOR

Page 3
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

ACCENDO FIRE PROTECTION LLC
502 DEERING CENTER 3RD FLOOR

Page 4
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DROP	0.0	4.9	7.0	na	12.96	0.1	10	7.0
DR2	0.0	4.9	12.0	na	16.97	0.1	10	12.0
D1	0.0	4.9	7.0	na	12.96	0.1	10	7.0
100	130.5	K = K @ LN2	12.65	na	16.97			
102	130.5	K = K @ LN2	13.16	na	17.31			
104	130.5	K = K @ LINE	13.16	na	17.26			
103	130.5	K = K @ LINE	13.66	na	17.58			
101	130.5		13.86	na				
105	130.5		13.95	na				
106	130.5		14.41	na				
107	130.5		21.26	na				
108	130.5		22.68	na				
109	108.0		40.23	na				
110	108.0		42.86	na				
17	108.0		42.91	na				
18	108.0		42.92	na				
TOR	108.0		42.95	na				
BFP	108.0		42.96	na				
BASE	101.0		53.68	na				
TEST	100.0		54.3	na				

The maximum velocity is 14.53 and it occurs in the pipe between nodes 106 and 107

Final Calculations - Hazen-Williams - 2007

ACCENDO FIRE PROTECTION LLC
502 DEERING CENTER 3RD FLOOR

Page 5
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DROP to LINE	0 0	4.90	12.96 12.96	1 1.101	N O	7.0 5.0 0.0	2.000 12.000 14.000	150 0.0305	7.000 0.0 0.427		Vel = 4.37	
LINE			0.0 12.96						7.427		K Factor = 4.76	
DR2 to LN2	0 0	4.90	16.97 16.97	1 1.101	N O	7.0 5.0 0.0	1.000 12.000 13.000	150 0.0502	12.000 0.0 0.653		Vel = 5.72	
LN2			0.0 16.97						12.653		K Factor = 4.77	
D1 to L1	0 0	4.90	12.96 12.96	1 1.101	O	5.0 0.0 0.0	1.000 5.000 6.000	150 0.0305	7.000 0.0 0.183		Vel = 4.37	
L1			0.0 12.96						7.183		K Factor = 4.84	
100 to 101	130.500 130.500	4.77	16.97 16.97	1 1.101	O	5.0 0.0 0.0	19.080 5.000 24.080	150 0.0502	12.653 0.0 1.210		K = K @ LN2 Vel = 5.72	
101			0.0 16.97						13.863		K Factor = 4.56	
102 to 106	130.500 130.500	4.77	17.31 17.31	1 1.101	O	5.0 0.0 0.0	19.080 5.000 24.080	150 0.0521	13.160 0.0 1.255		K = K @ LN2 Vel = 5.83	
106			0.0 17.31						14.415		K Factor = 4.56	
104 to 105	130.500 130.500	4.76	17.26 17.26	1 1.101	O	5.0 0.0 0.0	10.250 5.000 15.250	150 0.0518	13.164 0.0 0.790		K = K @ LINE Vel = 5.82	
105			0.0 17.26						13.954		K Factor = 4.62	
103 to 105	130.500 130.500	4.76	17.58 17.58	1 1.101	O	5.0 0.0 0.0	0.500 5.000 5.500	150 0.0536	13.659 0.0 0.295		K = K @ LINE Vel = 5.92	
105			0.0 17.58						13.954		K Factor = 4.71	
101 to 105	130.500 130.500		16.97 16.97	1.25 1.394		0.0 0.0 0.0	5.750 0.0 5.750	150 0.0158	13.863 0.0 0.091		Vel = 3.57	
105 to 106	130.500 130.500		34.84 51.81	1.25 1.394		0.0 0.0 0.0	3.670 0.0 3.670	150 0.1256	13.954 0.0 0.461		Vel = 10.89	
106 to 107	130.500 130.500		17.32 69.13	1.25 1.394	2N O	16.0 6.0 0.0	10.000 22.000 32.000	150 0.2138	14.415 0.0 6.843		Vel = 14.53	
107 to 108	130.500 130.500		0.0 69.13	1.25 1.394	O	6.0 0.0 0.0	0.625 6.000 6.625	150 0.2139	21.258 0.0 1.417		Vel = 14.53	
108 to 109	130.500 108		0.0 69.13	1.25 1.394	O N	6.0 8.0 0.0	22.500 14.000 36.500	150 0.2139	22.675 9.745 7.806		Vel = 14.53	

Final Calculations - Hazen-Williams

ACCENDO FIRE PROTECTION LLC
502 DEERING CENTER 3RD FLOOR

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
109 to 110	108 108		0.0 69.13	1.5 1.682	E T	4.95 9.9 20.350	120 0.1295	40.226 0.0 2.635			Vel = 9.98
110 to 17	108 108		0.0 69.13	4 4.26	T	26.334 0.0 35.834	120 0.0014	42.861 0.0 0.050			Vel = 1.56
17 to 18	108 108		0.0 69.13	4 4.26		0.0 0.0 6.920	120 0.0014	42.911 0.0 0.010			Vel = 1.56
18 to TOR	108 108		0.0 69.13	4 4.26	2l	18.434 0.0 22.144	120 0.0014	42.921 0.0 0.031			Vel = 1.56
TOR to BFP	108 108		0.0 69.13	4 4.26		0.0 0.0 7.500	120 0.0015	42.952 0.0 0.011			Vel = 1.56
BFP to BASE	108 101		0.0 69.13	4 4.26	Zca	0.0 0.0 2.000	120 0.0010	42.963 10.715 0.002		** Fixed Loss = 7.683	Vel = 1.56
BASE to TEST	101 100		0.0 69.13	4 4.1	2L T G	17.44 29.067 2.907 149.414	140 0.0013	53.680 0.433 0.190			Vel = 1.68
TEST			0.0 69.13					54.303			K Factor = 9.38