

**. . . Fire Protection by Computer Design**

ACCENDO FIRE PROTECTION LLC  
38 ADDITON RD  
GREENE, MAINE 04236  
207-946-6182

Job Name : 502 DEERING CENTER MERCANTILE  
Drawing : 1 OF 1  
Location : PORTLAND, MAINE  
Remote Area : 1  
Contract : 17-1010  
Data File : 17-1019 205 DEERING MERCANTILE.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**Project name:** 502 DEERING CENTER MERCANTILE  
**Location:** PORTLAND, MAINE  
**Drawing no:** 1 OF 1  
**Date:** 6/20/17

**Design**

**Remote area number:** 1  
**Remote area location:** REAR COMMERCIAL  
**Occupancy classification:** OH II  
**Density:** .2 - Gpm/SqFt  
**Area of application:** 1059 - SqFt  
**Coverage per sprinkler:** 120 - SqFt  
**Type of sprinklers calculated:** 1/2" 5.6K RECESSED PENDENTS  
**No. of sprinklers calculated:** 12  
**In-rack demand:** - GPM  
**Hose streams:** 250 - GPM  
**Total water required (including hose streams):** 573.91 - GPM @ 55.6825 - Psi  
**Type of system:** WET  
**Volume of dry or preaction system:** - Gal

**Water supply information**

**Date:** ?  
**Location:** CORNER OF HARTLEY AND STEVENS AVE  
**Source:** PORTLAND WATER DISTRICT

**Name of contractor:** ACCENDO FIRE PROTECTION LLC  
**Address:** 38 ADDITON RD / / GREENE, MAINE 04236  
**Phone number:** 207-946-6182  
**Name of designer:** JWD  
**Authority having jurisdiction:** SFMO, PORTLAND FIRE  
**Notes: (Include peaking information or gridded systems here.)** HYDRAULICALLY REMOTE AREA  
REVISED PER NFPA 13 2016 ED. SEC. 11.2.3.2.3.1


# Water Supply Curve C

ACCENDO FIRE PROTECTION LLC  
502 DEERING CENTER MERCANTILE

Page 2  
Date

City Water Supply:  
C1 - Static Pressure : 61  
C2 - Residual Pressure: 60  
C2 - Residual Flow : 1061

Demand:  
D1 - Elevation : 3.898  
D2 - System Flow : 572.149  
D2 - System Pressure : 53.894  
Hose ( Demand ) :  
D3 - System Demand : 572.149  
Safety Margin : 6.787



# Fittings Used Summary

ACCENDO FIRE PROTECTION LLC  
502 DEERING CENTER MERCANTILE

Page 3  
Date

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
Length Units                     Feet  
Flow Units                        US Gallons per Minute  
Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

ACCENDO FIRE PROTECTION LLC  
502 DEERING CENTER MERCANTILE

Page 4  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DROP	0.0	5.6	18.37	na	24.0	0.2	120	7.0
DR	0.0	5.6	7.0	na	14.82	0.1	120	7.0
D1	0.0	5.6	7.0	na	14.82	0.1	120	7.0
1	109.0	K = K @ LINE	37.91	na	25.53			
2	109.0	K = K @ LINE	38.16	na	25.61			
3	109.0	K = K @ LINE	35.29	na	24.63			
4	109.0	K = K @ LINE	35.52	na	24.71			
5	109.0	K = K @ LINE	36.36	na	25.0			
6	109.0	K = K @ LINE	33.5	na	24.0			
7	109.0	K = K @ LINE	33.72	na	24.08			
8	109.0	K = K @ LINE	34.25	na	24.27			
9	109.0	K = K @ LN	34.95	na	31.7			
10A	109.0	K = K @ L1	34.72	na	32.48			
15	109.0	5.6	37.23	na	34.17	0.15	120	7.0
10	109.0		37.89	na				
11	109.0		37.91	na				
12	109.0		38.06	na				
13	109.0		39.01	na				
14	109.0		39.08	na				
16	109.0	K = K @ LINE	39.2	na	25.96			
17	108.0		39.66	na				
18	108.0		40.3	na				
TOR	108.0		40.93	na				
BFP	108.0		41.11	na				
BASE	101.0		50.19	na				
TEST	100.0		53.89	na				

The maximum velocity is 15.02 and it occurs in the pipe between nodes 9 and 10

Final Calculations - Hazen-Williams - 2007

ACCENDO FIRE PROTECTION LLC  
502 DEERING CENTER MERCANTILE

Page 5  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DROP to LINE	0 0	5.60	24.00 24.0	1 1.049	T	5.0 0.0 0.0	78.000 5.000 83.000	120 0.1823	18.367 0.0 15.134		Vel = 8.91	
LINE			0.0 24.00						33.501		K Factor = 4.15	
DR to LN	0 0	5.60	14.82 14.82	1 1.049	E T	2.0 5.0 0.0	1.500 7.000 8.500	120 0.0747	7.000 0.0 0.635		Vel = 5.50	
LN			0.0 14.82						7.635		K Factor = 5.36	
D1 to L1	0 0	5.60	14.82 14.82	1 1.049	E	2.0 0.0 0.0	1.000 2.000 3.000	120 0.0747	7.000 0.0 0.224		Vel = 5.50	
L1			0.0 14.82						7.224		K Factor = 5.51	
1 to 2	109 109	4.15	25.53 25.53	1.5 1.682		0.0 0.0 0.0	12.000 0.0 12.000	120 0.0205	37.912 0.0 0.246		K = K @ LINE Vel = 3.69	
2 to 13	109 109	4.15	25.62 51.15	1.5 1.682	T	9.9 0.0 0.0	1.625 9.900 11.525	120 0.0742	38.158 0.0 0.855		K = K @ LINE Vel = 7.39	
13			0.0 51.15						39.013		K Factor = 8.19	
3 to 4	109 109	4.15	24.63 24.63	1.5 1.682		0.0 0.0 0.0	12.000 0.0 12.000	120 0.0192	35.294 0.0 0.230		K = K @ LINE Vel = 3.56	
4 to 5	109 109	4.15	24.72 49.35	1.5 1.682		0.0 0.0 0.0	12.000 0.0 12.000	120 0.0694	35.524 0.0 0.833		K = K @ LINE Vel = 7.13	
5 to 12	109 109	4.15	25.00 74.35	1.5 1.682	T	9.9 0.0 0.0	1.625 9.900 11.525	120 0.1482	36.357 0.0 1.708		K = K @ LINE Vel = 10.74	
12			0.0 74.35						38.065		K Factor = 12.05	
6 to 7	109 109	4.15	24.00 24.0	1.5 1.682		0.0 0.0 0.0	12.000 0.0 12.000	120 0.0183	33.501 0.0 0.220		K = K @ LINE Vel = 3.47	
7 to 8	109 109	4.15	24.08 48.08	1.5 1.682		0.0 0.0 0.0	8.000 0.0 8.000	120 0.0661	33.721 0.0 0.529		K = K @ LINE Vel = 6.94	
8 to 9	109 109	4.15	24.27 72.35	1.5 1.682		0.0 0.0 0.0	5.000 0.0 5.000	120 0.1408	34.250 0.0 0.704		K = K @ LINE Vel = 10.45	
9 to 10	109 109	5.36	31.70 104.05	1.5 1.682	T	9.9 0.0 0.0	0.750 9.900 10.650	120 0.2759	34.954 0.0 2.938		K = K @ LN Vel = 15.02	
10			0.0 104.05						37.892		K Factor = 16.90	

# Final Calculations - Hazen-Williams

ACCENDO FIRE PROTECTION LLC  
502 DEERING CENTER MERCANTILE

Page 6  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10A to 11	109 109	5.51	32.48 32.48	1 1.049	T 0.0	5.0 5.000 10.000	120 0.3191	34.715 0.0 3.191		K = K @ L1 Vel = 12.06	
11			0.0 32.48					37.906		K Factor = 5.28	
15 to 18	109 108	5.60	34.17 34.17	1 1.049	T 0.0	5.0 5.000 7.540	120 0.3505	37.228 0.433 2.643		Vel = 12.68	
18			0.0 34.17					40.304		K Factor = 5.38	
10 to 11	109 109		104.05 104.05	3 3.26	0.0 0.0	1.290 0.0 1.290	120 0.0109	37.892 0.0 0.014		Vel = 4.00	
11 to 12	109 109		32.48 136.53	3 3.26	0.0 0.0	8.710 0.0 8.710	120 0.0183	37.906 0.0 0.159		Vel = 5.25	
12 to 14	109 109		74.35 210.88	3 3.26	T 0.0	20.159 0.0 24.989	120 0.0406	38.065 0.0 1.015		Vel = 8.11	
14			0.0 210.88					39.080		K Factor = 33.73	
13 to 14	109 109		51.15 51.15	3 3.26	T 0.0	20.159 0.0 22.659	120 0.0030	39.013 0.0 0.067		Vel = 1.97	
14 to 16	109 109		210.87 262.02	4 4.26	0.0 0.0	7.040 0.0 7.040	120 0.0165	39.080 0.0 0.116		Vel = 5.90	
16 to 17	109 108	4.15	25.96 287.98	4 4.26	0.0 0.0	1.500 0.0 1.500	120 0.0200	39.196 0.433 0.030		K = K @ LINE Vel = 6.48	
17 to 18	108 108		0.0 287.98	4 4.26	T 0.0	26.334 0.0 32.834	120 0.0196	39.659 0.0 0.645		Vel = 6.48	
18 to TOR	108 108		34.17 322.15	4 4.26	2l 0.0	18.434 0.0 25.934	120 0.0241	40.304 0.0 0.626		Vel = 7.25	
TOR to BFP	108 108		0.0 322.15	4 4.26	0.0 0.0	7.500 0.0 7.500	120 0.0243	40.930 0.0 0.182		Vel = 7.25	
BFP to BASE	108 101		0.0 322.15	4 4.26	Zca 0.0	2.000 0.0 2.000	120 0.0240	41.112 9.029 0.048		* * Fixed Loss = 5.997 Vel = 7.25	
BASE to TEST	101 100		0.0 322.15	4 4.1	2L T G	17.44 29.067 2.907	100.000 49.414 149.414	140 0.0219	50.189 0.433 3.272		Vel = 7.83
TEST			0.0 322.15					53.894		K Factor = 43.88	