Portland, Maine



Yes. Life's good here.



Permitting and Inspections Department Michael A. Russell, MS, Director

Non-Water Based Fire Suppression System Permit Application

Reviewed for Code Compliance Permitting and Inspections Department Approved with Conditions

04/26/2018

A permit is required for non-water based fire suppression systems. Full-sized plans and details in PDF format and this application form shall be submitted. All applications shall be submitted online via the Citizen Self Service portal. Refer to the attached documents for complete instructions. Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided. All installations must comply with NFPA and the Fire Department Technical Standards.

Construction Addre	ess: 476 STEVE	ENS AVE		
Tax Assessor's CBL: Chart # Block # Lot #				
Cost of work: # 1,000 00				
Exact location (within structure): Kitchen				
Type of occupancy (NFPA & ICC):				
Building Owner: JEREMY@ELSMEREBBQ.COM				
Managing Supervisor:				
Supervisor phone:	S	upervisor email:		
Installing Contracto	r: ALLSTATE FIR	ZE License	No.: CR-46	12 MA
Installing Contractor: ALLSTATE FIRE License No.: CR-4612 MA Contractor phone: 9783041506 Contractor email: LMULNCALLSTATEBOS.				
The suppression work to be done will be:				
O New	O Renovation (Addition to exis	sting system	
Is this an amendme	at to an existing permit?	Yes, Permit No.	:	O No
System type: UL 300				
NFPA Standard*:	96/174		Edition: 2014	
Name of person to contact when permit is ready: LINC MULNO				
Address: 44 6 ARDEN ST				
City, State & Zip: DANVERS, MA				
***************************************	304 1506	Email: $\angle MU$	ILNOC ALLSTA	reposico.M

Separate permits are required for internal and external plumbing and electrical installations. For questions on Fire Department requirements, call the Fire Prevention Officer at (207) 874-8405.



Reviewed for Code Compliance Permitting and Inspections Department Approved with Conditions

04/26/2018

Department of Fire Services

CC-001034

Fire Equipment Certificate of Competency

Stephen G Keefe 7 Monument Hill Road Pelham NH 03076

Expiration Date 06/29/2019

State Fire Marshal Ray Gunty



The Commonwealth of Massachusetts Department of Fire Services





This is to certify that in accordance with all Massachusetts laws and regulations a Fire Equipment Certificate of Registration is hereby issued to:

Expiration Date: 11/10/2019

All State Fire Equipment Boston

P.O. Box 1025

Lynnfield MA 01940

Restrictions or Secondary License Type: CR - 42 Portable Fire Extinguishers

CR - 44 Special Hazard (Pre-Engineered)

CR - 43 Special Hazard (Engineered)



Reviewed for Code Compliance Permitting and Inspections Department **Approved with Conditions**

04/26/2018

Ken J Osterbuy

State Fire Marshal

Post in a conspicuous place. Verify the status of this Certificate at www.mass.gov/dfs