

All State Fire Equipment

A Division of the Allstate Family of Fire Suppression Companies

P.O. Box 1025
Lynnfield, MA 01940
866-542-3473

Pre-Engineered System Inspection Report

Date of Service: 6/1/2018 Time: 7:43 AM PM

Annual / Semi-Annual / Recharge / Installation / Renovation / Test

Customer / Location

Name: Ellsmere
 Address: 476 Stevens Ave
 City, ST, Zip: Portland ME 04103
 Owner / Manager: Jeremy Rush
 Phone: 207-807-8057
 Email: info@ellsmerebbq.com

System Information: <u>101-30 4/18 2 Supplies</u>
Make: <u>Ansul</u>
Model: <u>R102DT</u>
Size: <u>6 Gal St</u>
Control Head Type / Location: <u>ElectricOEM/ In Cabinet</u>
Location of Gas Valve: <u>N/A</u>

- 1 System interlocked with building fire alarm
- 2 All tamper seals intact. No evidence of tampering
- 3 All appliances properly covered w/ correct nozzles
- 4 Duct(s) & plenum properly covered w/ correct nozzles
- 5 Filters in place at time of inspection
- 6 Pressure gauge in acceptable range
- 7 Checked cartridge weight
- 8 Cylinder within hydrotest date Due 2030x2
- 9 Inspected cylinder & mount
- 10 Checked operation of detection line
- 11 # of fusible links 360 450 500 other
- 12 Replaced fusible links

Yes No N/A

Yes	No	N/A
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

- 13 Checked operation of manual release
- 14 Checked operation of micro-switch
- 15 Checked operation of gas valve (MECH / ELEC)
- 16 Piping / conduit securely braced
- 17 Nozzles cleaned
- 18 Proper nozzle caps/covers in place Qty 8
- 19 System operational & armed
- 20 Fan warning sign on hood
- 21 K-Class fire extinguisher in cooking area
- 22 Allstate Fire Equipment sticker on Automan
- 23 Service & certification tag on system
- 24 System meets U.L. 300 Standards

Yes No N/A

Yes	No	N/A
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Cooking Appliances (left to right)
Wood Fire Grill

Safety Notice: Non-compliant systems may fail to extinguish/suppress a fire. Below are non-compliant conditions which require immediate attention. All State Fire Equipment assumes no responsibility for system performance if these conditions are not corrected and/or verified by an authorized agent of All State Fire Equipment.

Comments / Non-Compliance:

All State Fire Equipment Agent: Jamie Medeiros Date: 6/1/2018

Customer's Authorized Agent: Jeremy Rush Date: 6/1/2018

If testing for Authority Having Jurisdiction:

AHJ Print: Mike Clinton

Testing Date: _____

AHJ Signature: *Mike P. Clinton*

Jurisdiction: _____