
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager SINCLAIR MARK A &		Inspector Tammy Munson	Inspection Date 10/8/2008
Location 27 BRENTWOOD ST	CBL 135 E021001	Status	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-116.5	Interior	first		kitchen area	
Violation:	Fire Protection				
Notes:	All smoke detectors shall be maintained in safe working condition				
2) 6-108.b	Interior	first		rear bedroom	
Violation:	Interior floors, walls, ceilings and doors				
Notes:	Close in hole in bedroom wall. It shall be insulated, sided, and the interior shall be finished				
3) 6-113.5	Interior	first		Bathroom	
Violation:	Maintenance of lighting fixtures				
Notes:	Light fixture over shower in disrepair.				
4) 6-113.5	Interior	first		Bathroom	
Violation:	Maintenance of lighting fixtures				
Notes:	Open wires over shower - wires need to be contained in a covered junction box.				

Comments: