

24-26 Crosby Street

DRG-CTR II



SHAW-WALKER

#8503-R

October 23, 1973

Mr. Thomas Leo
24 Crosby Street
Portland, Maine

Re: 24-26 Crosby Street

Dear Mr. Leo:

Your property has been surveyed by the Portland Housing Inspection Division, Health Department, in conjunction with the Deering Center Neighborhood Conservation Program, and was found to meet the standards established by the Housing Code.

Congratulations are extended to you for the general condition of your property. Good maintenance is the best way to preserve the useful life of your property and neighborhood.

If we can be of further help, please feel free to call on us.

Sincerely yours,

Lyle D. Noyes
Lyle D. Noyes
Chief of Housing Inspections

Inspector *Robert Bailey*

LDN/cv

Housing Inspection Division

(1) Insp. Name R. Bailey

(1) Insp. Date	(3) Insp. Type	(4) Project Code	(5) Assr's	(6) Start	(7) Bl.	(7) Lot	(8) Census	Tract	(9) Blk.	(10) Insp.	(11) Form No.	
7/19/72	W	2422	135		E	L				01	051	
(12) House No.	(13) Sec. H No.	(14) Suff.	(15) Direct.	(16) Street Name				(17) St. Design.				
24-24				Crosby				ST				
(18) Owner or Agent: Thomas Leo									(19) Status			(20) Bldg's Rating
21) Address: 24 Crosby ST									00			1
22) City and State: Portland Me									Zip Code			04102
(23) U. Units	(24) Occ. D.U. 's	(25) Km. Units	(26) Occ. R.U. 's	(27) No. Occupants	(28) Con'l. U.	(29) Bldg. Type	(30) Stories	(31) Const. Mat.	(32) O.B. 's	(33) C.H.	(34) Photo	
3	3			11	0	DE	3	Wood	NO	NO	YES	
(35) House E.		(36) Normal Land Use	(37) U. D.	(38) Orig. Ist. Res.	(39) Fin. Res.	(40) Disp.	(41) Closing Date					
P-3		Res										

[illegible]

Housing Inspection Division

[illegible]

Health Department
DWELLING UNIT SCHEDULE

DNELLING UNIT SCHEDULE

(2) INSP.

(3) FORM NO.

C) INSP. DATE					
1	0	1	1	7	3

(4) TENANT'S NAME

(5) Flr. #	(6) Location	(7) Rmg. Tp.	(8) #Rms	(9) #Peo	(10) #All'd	(11) Slp. Rms
------------	--------------	--------------	----------	----------	-------------	---------------

Child Un. 10	(3) Child 1-6	(4) + Lead Survey - Results	(15) Rent.	(16) Rent Code	(17) Furn.	(18) Heat	(19) Hot Water	(20) Dual Eggs	(21) Ck'ng	(22) Lav.	(23) Bath	(24) Flush
-----------------	------------------	--------------------------------	------------	-------------------	------------	-----------	-------------------	-------------------	------------	-----------	-----------	------------

[illegible]

Housing Inspection Division

DWELLING UNIT SCHEDULE

[illegible]

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

December 09, 1994

LEO JOANN & ROBERT E JTS
26 CROSBY ST
PORTLAND ME 04103

Re: 26 Crosby St
CBL: 135- - E-006-001-01
DU: 3

Dear Mr. & Mrs. Leo:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above referred property.


Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:


- | | |
|------------------------------------|--------|
| 1. INT - CELLAR - | |
| STAIRS ARE MISSING A HANDRAIL | 108.10 |
| 2. INT - CELLAR - | |
| IMPROPER ELECTRICAL SERVICE GROUND | 113.50 |

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,


Kevin Carroll
Code Enforcement Officer


Marge Schuckal
Asst. Chief of Inspection Services

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

December 09, 1994

LEG JOANN & ROBERT E JTS
26 CROSBY ST
PORTLAND ME 04103

Re: 26 Crosby St
CBL: 135- - E-006-001-01
DU: 3

Dear Mr. & Mrs. Leo:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above referred property.


Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:


- | | |
|------------------------------------|--------|
| 1. INT - CELLAR - | |
| STAIRS ARE MISSING A HANDRAIL | 108.10 |
| 2. INT - CELLAR - | |
| IMPROPER ELECTRICAL SERVICE GROUND | 113.50 |

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,


Kevin Carroll
Code Enforcement Officer


Marge Schmuckal
Asst. Chief of Inspection Services

