


**APARTMENT
WATER FLOW**

UNIT	MBH	GPM
503	10.21	1.00
504	6.24	1.00
505	6.94	1.00
506	8.51	1.00
508	7.37	1.00
509	8.51	1.00
515	8.51	1.00
516	6.24	1.00
518	10.21	1.00
519	6.24	1.00
523	7.94	1.00

BRANCH PIPING TO INDIVIDUAL ZONES, COILS AND CABINET UNIT HEATERS TO BE 3/4" PEX UNLESS NOTED OTHERWISE. RUN PEX JOINT-FREE FROM MAINS TO HEATING UNITS.



Prepared For: **MOTHERHOUSE LLC**
 Portland, ME 04103

Consulting Engineer: **MECHANICAL SYSTEMS ENGINEERS**
 ROYAL RIVER CENTER, UNIT 10B
 10 FOREST FALLS (201) 846-3441
 FACEBOOK: MECHANICAL SYSTEMS ENGINEERS
 © COPYRIGHT 2016

Architect: **ARCHETYPE architects**
 48 Union Wharf Portland, Maine 04101
 (207) 773-6022 ARCHETYPE@ARCHETYPEDA.COM

Project: **MOTHERHOUSE SENIOR HOUSING**
 PORTLAND, MAINE

Revisions:
 Permit Set: 15 February 2016

Date: 15 FEB. 2016
 Scale: 3/32" = 1'-0"

**FIFTH FLOOR
MECHANICAL
PIPING**

M5
MSE PROJECT 1530

