

# ELECTRICAL PERMIT

## City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations  
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,  
 National Electrical code and the following specification:

Date June 20, 1996

Permit # 17164

LOCATION: 242 Walton 605 Stevens

136-E-006

OWNER Catherine McCauley H.S. ADDRESS \_\_\_\_\_

OUTLETS						TOTAL EACH FEE			
FIXTURES	4	Receptacles (number of)	1	Switches		Smoke Detector	5	.20	1.00
		incandescent		fluorescent				.20	
		fluorescent strip						.20	
SERVICES		Overhead							
	X	Underground			100	TTL AMPSTO AMPS	800	15.00	
TEMPORARY SERV.						AMPS OVER	800	25.00	15.00
		Overhead						25.00	
		Underground						25.00	
METERS		(number of)						1.00	
MOTORS	1	(number of)						2.00	2.00
RESID/COM		Electric units					1	2.00	
HEATING		oil/gas units						1.00	
APPLIANCES		Ranges		Cook Tops		Wall Ovens		5.00	
		Water heaters		Fans		Dryers		2.00	
Disposals		Dishwasher		Compactors		Others (denote)		2.00	
MISC. (number of)		Air Cond/win						3.00	
		Air Cond/cent						10.00	
		Signs						5.00	
		Pools						10.00	
		Alarms/res						5.00	
		Alarms/com						15.00	
		Heavy Duty						2.00	
		Outlets						25.00	
		Circus/Carnv						5.00	
		Alterations						15.00	
		Fire Repairs						1.00	
		E Lights						20.00	
		E Generators						4.00	
TRANSFORMER		Panels						5.00	
		0-25 Kva						8.00	
		25-200 Kva						10.00	
		Over 200 Kva							
						TOTAL AMOUNT DUE			
						MINIMUM FEE/COMMERCIAL	35.00		
						MINIMUM FEE	25.00		25.00

INSPECTION: Will be ready NOW or will call \_\_\_\_\_  
 (located in the ballfield)

CONTRACTORS NAME Pickrell Electric, Inc.

ADDRESS 79 King Street, Westbrook 04092

TELEPHONE 856-0272

MASTER LICENSE No. 17164

LIMITED LICENSE No. \_\_\_\_\_

SIGNATURE OF CONTRACTOR

*[Handwritten Signature]*



ELECTRICAL INSTALLATIONS—

Permit Number

17164

Location

242 Winton St.

Owner

Catherine Mc Carley H&S

Date of Permit

6/20/96

Final Inspection

6/25/96

By Inspector

*[Signature]*

INSPECTION: Service

6/25/96 by *[Signature]*

Service called in

6/25/96

Closing-in

by

PROGRESS INSPECTIONS:

6/25/96	(SERVICE)
	(OUT BUILDING)

DATE:

REMARKS:

6/25/96 Needs NO box on aluminum connections & label meter panel, & disconnect

SIGNATURE OF CONTRACTOR

CONTRACTORS NAME  
ADDRESS  
TELEPHONE  
MASTER LICENSE NO.  
LIMITED LICENSE NO.

INSPECTION

MINIMUM FEE COMMERCIAL \$5.00

\$5.00

TOTAL AMOUNT DUE

Over 500 Kva  
25-500 Kva  
0-25 Kva

TRANSFORMER

F. Generators  
F. Lights  
Fire Repairs

A. Alterations  
C. Other Work

Outlets  
Heavy Duty

Aluminum  
Aluminox

Water Heaters  
Dishwashers

Compressors  
Oilers (bonds)

Fans  
Driers

Electric Units  
Gas Units

Fluorescent  
Incandescent

Places  
(to)

Services  
Fixtures

Permit  
Portland, Me.