

**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
946-3473

Job Name : MOTHERHOUSE SENIOR HOUSING  
Building : WOOD FRAMED  
Location : 1ST FLOOR- COMMUNITY ROOM AREA  
System : 1  
Contract : C17011  
Data File : MOTHERHOUSE-1ST FLR-COMMUNITY RM.WXF

Hydraulic Design Information Sheet

Name - MOTHERHOUSE SENIOR HOUSING Date - 7/27/2017  
 Location - 1ST FLOOR- COMMUNITY ROOM AREA  
 Building - WOOD FRAMED System No. - 1  
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C17011  
 Calculated By - T. PRAY Drawing No. - 1 OF 5  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 9'-6"  
 Occupancy - LIGHT HAZARD

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 943	System Type	Sprinkler/Nozzle
	Density	- .1	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 154	( ) Dry	Model VK305
E	Elevation at Highest Outlet	- 126.25	( ) Deluge	Size 1/2"
S	Hose Allowance - Inside	-	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 160.04 Press Required - 44.09 AT BOR  
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 6/2/2017		Cap. -
T	Time of Test - 6:30 AM	Rated Cap.-	Elev.-
E	Static Press - 58	@ Press -	
R	Residual Press - 56	Elev. -	Well
S	Flow - 1061		Proof Flow
U	Elevation - 122		

P Location - HYDRANTS ARE LOCATED ON STEVENS AVE, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:

# Water Supply Curve (C)

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING


Page 2  
Date 7/27/2017

### City Water Supply:

C1 - Static Pressure : 58  
C2 - Residual Pressure: 56  
C2 - Residual Flow : 1061

### Demand:

D1 - Elevation : 1.841  
D2 - System Flow : 160.044  
D2 - System Pressure : 42.981  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 100  
D3 - System Demand : 260.044  
Safety Margin : 14.871



# Fittings Used Summary

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING

Page 3  
Date 7/27/2017

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
A	Generic Alarm Valve	0	0	0	0	0	0	7.7	21.5	0	17	17	27	29	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING

Page 4  
Date 7/27/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DO01	0.0	5.6	7.0	na	14.82	0.1	148	7.0
60	126.25	5.6	14.05	na	20.99	0.1	110	7.0
61	126.25	5.6	15.62	na	22.13	0.1	110	7.0
61A	126.25		18.78	na				
62	126.25	5.6	7.56	na	15.4	0.1	154	7.0
63	126.25	5.6	7.83	na	15.67	0.1	154	7.0
111A	126.25		8.55	na				
64	126.25	5.6	12.28	na	19.62	0.1	110	7.0
65	126.25	5.6	14.38	na	21.24	0.1	110	7.0
66	126.25	5.6	15.91	na	22.34	0.1	110	7.0
67	126.25	K = K @ EQ01	17.35	na	22.65			
68	126.25		18.56	na				
110	126.25		19.22	na				
111	126.25		19.33	na				
112	126.25		20.2	na				
113	126.25		20.54	na				
114	126.25		22.19	na				
115	126.25		24.38	na				
119	126.25		26.66	na				
106	126.25		36.53	na				
604	126.42		39.82	na				
605	125.92		40.41	na				
TOR	122.58		42.14	na				
HDR	118.92		44.09	na				
6UG	117.42		44.77	na				
TEST	122.0		42.98	na	100.0			

The maximum velocity is 16.01 and it occurs in the pipe between nodes 61 and 61A

# Final Calculations - Hazen-Williams

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING

Page 5  
Date 7/27/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DO01 to EQ01	14.82	1.049 120	1T	5.0 0.0	0.670 5.000	7.000 0.0			K Factor = 5.60	
	14.82	0.0748		0.0	5.670	0.424			Vel = 5.50	
	0.0 14.82						7.424		K Factor = 5.44	
60 to 61	20.99	1.049 120		0.0 0.0	11.000 0.0	14.052 0.0			K Factor = 5.60	
	20.99	0.1423		0.0	11.000	1.565			Vel = 7.79	
61 to 61A	22.13	1.049 120		0.0 0.0	5.875 0.0	15.617 0.0			K Factor = 5.60	
	43.12	0.5392		0.0	5.875	3.168			Vel = 16.01	
61A to 110	0.0	2.157 120	1T	12.307 0.0	14.670 12.307	18.785 0.0				
	43.12	0.0161		0.0	26.977	0.434			Vel = 3.79	
	0.0 43.12						19.219		K Factor = 9.84	
62 to 111A	15.40	1.049 120	1T	5.0 0.0	7.330 5.000	7.562 0.0			K Factor = 5.60	
	15.4	0.0803		0.0	12.330	0.990			Vel = 5.72	
	0.0 15.40						8.552		K Factor = 5.27	
63 to 111A	15.67	1.049 120	1T	5.0 0.0	3.670 5.000	7.833 0.0			K Factor = 5.60	
	15.67	0.0829		0.0	8.670	0.719			Vel = 5.82	
111A to 64	15.40	1.049 120		0.0 0.0	12.670 0.0	8.552 0.0				
	31.07	0.2940		0.0	12.670	3.725			Vel = 11.53	
64 to 65	19.62	1.38 120		0.0 0.0	11.000 0.0	12.277 0.0			K Factor = 5.60	
	50.69	0.1913		0.0	11.000	2.104			Vel = 10.87	
65 to 111	21.24	1.61 120	1T	8.0 0.0	20.670 8.000	14.381 0.0			K Factor = 5.60	
	71.93	0.1725		0.0	28.670	4.945			Vel = 11.34	
	0.0 71.93						19.326		K Factor = 16.36	
66 to 67	22.34	1.049 120		0.0 0.0	9.000 0.0	15.913 0.0			K Factor = 5.60	
	22.34	0.1597		0.0	9.000	1.437			Vel = 8.29	
67 to 68	22.65	1.38 120		0.0 0.0	7.920 0.0	17.350 0.0			K Factor @ node EQ01	
	44.99	0.1534		0.0	7.920	1.215			Vel = 9.65	
68 to 112	0.0	1.61 120	1T	8.0 0.0	14.580 8.000	18.565 0.0				
	44.99	0.0724		0.0	22.580	1.634			Vel = 7.09	
	0.0 44.99						20.199		K Factor = 10.01	
110 to 111	43.12	2.157 150		0.0 0.0	10.000 0.0	19.219 0.0				
	43.12	0.0107		0.0	10.000	0.107			Vel = 3.79	

# Final Calculations - Standard

Residential Fire Protection  
MOTHERHOUSE SENOIR HOUSING

Page 6  
Date 7/27/2017

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
111 to 113	71.93  115.05	2.157 120 0.0989	1J	10.461 0.0 0.0	1.790 10.461 12.251	19.326 0.0 1.212		Vel = 10.10		
	0.0 115.05					20.538		K Factor = 25.39		
112 to 113	44.99  44.99	2.157 120 0.0174	1J	10.461 0.0 0.0	9.000 10.461 19.461	20.199 0.0 0.339		Vel = 3.95		
113 to 114	115.05  160.04	2.157 120 0.1823		0.0 0.0 0.0	9.080 0.0 9.080	20.538 0.0 1.655		Vel = 14.05		
114 to 115	0.0  160.04	2.157 120 0.1822		0.0 0.0 0.0	12.000 0.0 12.000	22.193 0.0 2.187		Vel = 14.05		
115 to 119	0.0  160.04	2.157 120 0.1822		0.0 0.0 0.0	12.500 0.0 12.500	24.380 0.0 2.278		Vel = 14.05		
119 to 106	0.0  160.04	2.635 120 0.0688	2J 2I 1T	29.654 16.474 16.474	80.960 62.602 143.562	26.658 0.0 9.870		Vel = 9.42		
106 to 604	0.0  160.04	2.635 120 0.0688	1Z 1S 1G 2I	8.237 19.22 1.373 16.474	3.580 45.304 48.884	36.528 -0.074 3.361		Vel = 9.42		
604 to 605	0.0  160.04	4.26 120 0.0066	4I	36.868 0.0 0.0	20.170 36.868 57.038	39.815 0.217 0.378		Vel = 3.60		
605 to TOR	0.0  160.04	4.026 120 0.0087	2F 1E	8.0 10.0 0.0	14.000 18.000 32.000	40.410 1.447 0.279		Vel = 4.03		
TOR to HDR	0.0  160.04	4.026 120 0.0087	1A 1G 1T	17.0 2.0 20.0	3.670 39.000 42.670	42.136 1.585 0.372		Vel = 4.03		
HDR to 6UG	0.0  160.04	7.981 120 0.0003	1S 1E	45.0 18.0 0.0	11.000 63.000 74.000	44.093 0.650 0.023		Vel = 1.03		
6UG to TEST	0.0  160.04	6.16 140 0.0008	1L 1G 1T	12.911 4.304 43.037	180.000 60.252 240.252	44.766 -1.984 0.199		Vel = 1.72		
	100.00 260.04					42.981		Qa = 100.00 K Factor = 39.66		