

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
946-3473

Job Name : MOTHERHOUSE SENIOR HOUSING
Building : WOOD FRAMED
Location : 1ST FLOOR- LOBBY AREA
System : 1
Contract : C17011
Data File : MOTHERHOUSE-1ST FLR-LOBBY SW.WXF

Hydraulic Design Information Sheet

Name - MOTHERHOUSE SENIOR HOUSING Date - 7/27/2017
 Location - 1ST FLOOR- LOBBY AREA
 Building - WOOD FRAMED System No. - 1
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C17011
 Calculated By - T. PRAY Drawing No. - 1 OF 5
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 9'-7"
 Occupancy - LIGHT HAZARD

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 933	System Type	Sprinkler/Nozzle
	Density	- .1	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 120	() Dry	Model VK305
E	Elevation at Highest Outlet	- 126.59	() Deluge	Size 1/2"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 171.1 Press Required - 55.92 AT BOR
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 6/2/2017		Cap. -
T	Time of Test - 6:30 AM	Rated Cap.-	Elev.-
E	Static Press - 58	@ Press -	
R	Residual Press - 56	Elev. -	Well
S	Flow - 1061		Proof Flow
U	Elevation - 123		

P Location - HYDRANTS ARE LOCATED ON STEVENS AVE, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING


Page 2
Date 7/27/2017

City Water Supply:

C1 - Static Pressure : 58
C2 - Residual Pressure: 56
C2 - Residual Flow : 1061

Demand:

D1 - Elevation : 1.988
D2 - System Flow : 171.101
D2 - System Pressure : 54.840
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 271.101
Safety Margin : 3.000



Fittings Used Summary

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 3
Date 7/27/2017

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
A	Generic Alarm Valve	0	0	0	0	0	0	7.7	21.5	0	17	17	27	29	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
N	CPVC 90'Ell Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 4
Date 7/27/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DO01	0.0	4.9	7.04	na	13.0	0.0508	256	7.0
50	126.59	5.6	7.0	na	14.82	0.1	120	7.0
51	126.59	5.6	7.9	na	15.74	0.1	120	7.0
52	126.59	5.6	11.32	na	18.84	0.1	120	7.0
53	126.59	5.6	13.5	na	20.58	0.1	120	7.0
54	126.59	5.6	7.21	na	15.03	0.1	120	7.0
55	126.59	5.6	8.08	na	15.92	0.1	100	7.0
56	126.59	5.6	11.0	na	18.58	0.1	100	7.0
57	126.59	5.6	12.84	na	20.06	0.1	100	7.0
100	126.59		16.57	na				
58	126.59	4	12.88	na	14.35	0.0508	256	10.6
59	126.59	K = K @ EQ01	12.92	na	17.18			
100A	126.59		17.23	na				
101	125.92		22.99	na				
102	125.92		34.64	na				
103	125.92		40.69	na				
104	125.92		41.77	na				
105	125.92		47.84	na				
106	125.92		49.25	na				
604	125.92		51.73	na				
605	125.92		52.15	na				
TOR	122.58		53.92	na				
HDR	118.92		55.92	na				
6UG	117.42		56.6	na				
TEST	122.0		54.84	na	100.0			

The maximum velocity is 17.42 and it occurs in the pipe between nodes 101 and 102

Final Calculations - Hazen-Williams

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 5
Date 7/27/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DO01 to EQ01	13.00 13.0	1.049 120 0.0587	1T	5.0 0.0 0.0	1.170 5.000 6.170	7.044 0.0 0.362			K Factor = 4.90 Vel = 4.83	
	0.0 13.00						7.406		K Factor = 4.78	
50 to 51	14.82 14.82	1.049 120 0.0747		0.0 0.0 0.0	12.000 0.0 12.000	7.000 0.0 0.896			K Factor = 5.60 Vel = 5.50	
51 to 52	15.73 30.55	1.049 120 0.2850		0.0 0.0 0.0	12.000 0.0 12.000	7.896 0.0 3.420			K Factor = 5.60 Vel = 11.34	
52 to 53	18.84 49.39	1.38 120 0.1822		0.0 0.0 0.0	12.000 0.0 12.000	11.316 0.0 2.187			K Factor = 5.60 Vel = 10.59	
53 to 100	20.58 69.97	1.61 120 0.1639	1E	4.0 0.0 0.0	14.710 4.000 18.710	13.503 0.0 3.066			K Factor = 5.60 Vel = 11.03	
	0.0 69.97						16.569		K Factor = 17.19	
54 to 55	15.03 15.03	1.049 120 0.0768		0.0 0.0 0.0	11.420 0.0 11.420	7.208 0.0 0.877			K Factor = 5.60 Vel = 5.58	
55 to 56	15.93 30.96	1.049 120 0.2920		0.0 0.0 0.0	10.000 0.0 10.000	8.085 0.0 2.920			K Factor = 5.60 Vel = 11.49	
56 to 57	18.57 49.53	1.38 120 0.1832		0.0 0.0 0.0	10.000 0.0 10.000	11.005 0.0 1.832			K Factor = 5.60 Vel = 10.62	
57 to 100	20.07 69.6	1.61 120 0.1623	1E 1T	4.0 8.0 0.0	11.000 12.000 23.000	12.837 0.0 3.732			K Factor = 5.60 Vel = 10.97	
100 to 100A	69.97 139.57	2.157 120 0.1415		0.0 0.0 0.0	4.670 0.0 4.670	16.569 0.0 0.661			Vel = 12.25	
	0.0 139.57						17.230		K Factor = 33.62	
58 to 59	14.35 14.35	1.049 120 0.0701		0.0 0.0 0.0	0.670 0.0 0.670	12.877 0.0 0.047			K Factor = 4.00 Vel = 5.33	
59 to 100A	17.18 31.53	1.049 120 0.3022	2T	10.0 0.0 0.0	4.250 10.000 14.250	12.924 0.0 4.306			K Factor @ node EQ01 Vel = 11.70	
100A to 101	139.57 171.1	2.157 120 0.2062	3I	12.922 0.0 0.0	13.620 12.922 26.542	17.230 0.290 5.473			Vel = 15.02	
101 to 102	0.0 171.1	2.003 150 0.1957	2O 6R	20.0 6.0 0.0	33.500 26.000 59.500	22.993 0.0 11.647			Vel = 17.42	

Final Calculations - Standard

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 6
Date 7/27/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
102 to 103	-81.51 89.59	2.003 150 0.0591	1O 13R	10.0 13.0 0.0	79.290 23.000 102.290	34.640 0.0 6.049		Vel = 9.12		
103 to 104	0.0 89.59	2.003 150 0.0591		0.0 0.0 0.0	18.210 0.0 18.210	40.689 0.0 1.077		Vel = 9.12		
	0.0 89.59					41.766		K Factor = 13.86		
102 to 104	81.51 81.51	2.003 150 0.0497	2O 1N 15R	20.0 11.0 15.0	97.500 46.000 143.500	34.640 0.0 7.126		Vel = 8.30		
104 to 105	89.59 171.1	2.423 150 0.0775	1O 8R	12.0 16.0 0.0	50.460 28.000 78.460	41.766 0.0 6.078		Vel = 11.91		
105 to 106	0.0 171.1	2.635 120 0.0778	1I	8.237 0.0 0.0	9.840 8.237 18.077	47.844 0.0 1.406		Vel = 10.07		
106 to 604	0.0 171.1	2.635 120 0.0778	1Z 1S 1G	8.237 19.22 1.373	3.000 28.830 31.830	49.250 0.0 2.476		Vel = 10.07		
604 to 605	0.0 171.1	4.26 120 0.0075	4I	36.868 0.0 0.0	20.170 36.868 57.038	51.726 0.0 0.428		Vel = 3.85		
605 to TOR	0.0 171.1	4.026 120 0.0099	2F 1E	8.0 10.0 0.0	14.000 18.000 32.000	52.154 1.447 0.316		Vel = 4.31		
TOR to HDR	0.0 171.1	4.026 120 0.0099	1A 1G 1T	17.0 2.0 20.0	3.670 39.000 42.670	53.917 1.585 0.421		Vel = 4.31		
HDR to 6UG	0.0 171.1	7.981 120 0.0004	1S 1E	45.0 18.0 0.0	11.000 63.000 74.000	55.923 0.650 0.026		Vel = 1.10		
6UG to TEST	0.0 171.1	6.16 140 0.0009	1L 1G 1T	12.911 4.304 43.037	180.000 60.252 240.252	56.599 -1.984 0.225		Vel = 1.84		
	100.00 271.10					54.840		Qa = 100.00 K Factor = 36.61		