

**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
946-3473

Job Name : MOTHERHOUSE SENIOR HOUSING  
Building : WOOD FRAMED  
Location : 4TH FLOOR-UNIT (AREA#4)  
System : 1  
Contract : C17011  
Data File : MOTHERHOUSE-4TH FLR-UNIT.WXF

Hydraulic Design Information Sheet

Name - MOTHERHOUSE SENIOR HOUSING Date - 7/27/2017  
 Location - 4TH FLOOR-UNIT (AREA#4)  
 Building - WOOD FRAMED System No. - 1  
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C17011  
 Calculated By - T. PRAY Drawing No. - 4 OF 5  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 10'-6"  
 Occupancy - LIGHT HAZARD

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

E  
 M Area of Sprinkler Operation - 4 SPRK'S System Type Sprinkler/Nozzle  
 Density - .0508 (X) Wet Make VIKING  
 D Area Per Sprinkler - 256 ( ) Dry Model VK486  
 E Elevation at Highest Outlet - 163.42 ( ) Deluge Size 1/2"  
 S Hose Allowance - Inside - ( ) Preaction K-Factor 4.0  
 I Rack Sprinkler Allowance - ( ) Other Temp.Rat.155  
 G Hose Allowance - Outside - 100

N Note

Calculation Flow Required - 53.94 Press Required - 57.25 AT BOR  
 Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
 A Date of Test - 6/2/2017 Cap. -  
 T Time of Test - 6:30 AM Rated Cap.- Elev.-  
 E Static Press - 58 @ Press -  
 R Residual Press - 56 Elev. - Well  
 Flow - 1061 Proof Flow  
 S Elevation - 122

U Location - HYDRANTS ARE LOCATED ON STEVENS AVE, SEE PLOT PLAN

P Source of Information - PORTLAND WATER DISTRICT

C Commodity Class Location  
 O Storage Ht. Area Aisle W.  
 M Storage Method: Solid Piled % Palletized % Rack  
 M  
 ( ) Single Row ( ) Conven. Pallet ( ) Auto. Storage ( ) Encap.  
 S R ( ) Double Row ( ) Slave Pallet ( ) Solid Shelf ( ) Non  
 T A ( ) Mult. Row ( ) Open Shelf  
 O C

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G Horizontal Barriers Provided:  
 E

# Water Supply Curve (C)

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING


Page 2  
Date 7/27/2017

### City Water Supply:

C1 - Static Pressure : 58  
C2 - Residual Pressure: 56  
C2 - Residual Flow : 1061

### Demand:

D1 - Elevation : 17.939  
D2 - System Flow : 53.444  
D2 - System Pressure : 55.942  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 100  
D3 - System Demand : 153.444  
Safety Margin : 2.002



# Fittings Used Summary

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING

Page 3  
Date 7/27/2017

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
A	Generic Alarm Valve	0	0	0	0	0	0	7.7	21.5	0	17	17	27	29	0	0	0	0	0	0	0	0
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	28
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	120
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40	40
N	CPVC 90'El Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0	0
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING

Page 4  
Date 7/27/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
20	163.42	4	10.6	na	13.02	0.0508	256	10.6
21	163.42	4	10.72	na	13.1	0.0508	256	10.6
400A	163.42		11.2	na				
400	161.92		12.58	na				
22	163.42	4	11.6	na	13.62	0.0508	256	10.6
23	163.42	4	11.73	na	13.7	0.0508	256	10.6
401A	163.42		12.26	na				
401	161.92		13.69	na				
402	161.92		19.33	na				
403	161.92		27.67	na				
404	161.92		28.28	na				
406	161.92		30.05	na				
406A	161.92		34.85	na				
416	161.92		38.3	na				
601	161.92		38.44	na				
602	150.58		43.36	na				
603	138.5		48.6	na				
604	126.42		53.86	na				
605	125.92		54.13	na				
TOR	122.58		55.61	na				
HDR	118.92		57.25	na				
6UG	117.42		57.9	na				
TEST	122.0		55.94	na	100.0			

The maximum velocity is 11.23 and it occurs in the pipe between nodes 401 and 402

# Final Calculations - Hazen-Williams

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING

Page 5  
Date 7/27/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
20 to 400A	13.02 13.02	0.874 150 0.0947	1O	3.0 0.0 0.0	3.375 3.000 6.375	10.600 0.0 0.604			K Factor = 4.00 Vel = 6.96	
	0.0 13.02						11.204		K Factor = 3.89	
21 to 400A	13.10 13.1	0.874 150 0.0958	1O	3.0 0.0 0.0	2.040 3.000 5.040	10.721 0.0 0.483			K Factor = 4.00 Vel = 7.01	
400A to 400	13.02 26.12	1.101 150 0.1114	1O	5.0 0.0 0.0	1.500 5.000 6.500	11.204 0.650 0.724			Vel = 8.80	
400 to 401	0.0 26.12	1.101 150 0.1115		0.0 0.0 0.0	10.000 0.0 10.000	12.578 0.0 1.115			Vel = 8.80	
	0.0 26.12						13.693		K Factor = 7.06	
22 to 401A	13.62 13.62	0.874 150 0.1029	1O	3.0 0.0 0.0	3.375 3.000 6.375	11.600 0.0 0.656			K Factor = 4.00 Vel = 7.28	
	0.0 13.62						12.256		K Factor = 3.89	
23 to 401A	13.70 13.7	0.874 150 0.1040	1O	3.0 0.0 0.0	2.040 3.000 5.040	11.732 0.0 0.524			K Factor = 4.00 Vel = 7.33	
401A to 401	13.62 27.32	1.101 150 0.1211	1O	5.0 0.0 0.0	1.500 5.000 6.500	12.256 0.650 0.787			Vel = 9.21	
401 to 402	26.12 53.44	1.394 150 0.1329	1N 1O	8.0 6.0 0.0	28.460 14.000 42.460	13.693 0.0 5.642			Vel = 11.23	
402 to 403	0.0 53.44	1.394 150 0.1329	2O	12.0 0.0 0.0	50.750 12.000 62.750	19.335 0.0 8.337			Vel = 11.23	
403 to 404	-25.90 27.54	1.598 150 0.0201	1N	9.0 0.0 0.0	21.500 9.000 30.500	27.672 0.0 0.612			Vel = 4.41	
404 to 406	0.0 27.54	1.598 150 0.0200	1O	8.0 0.0 0.0	80.125 8.000 88.125	28.284 0.0 1.765			Vel = 4.41	
	0.0 27.54						30.049		K Factor = 5.02	
403 to 406	25.91 25.91	1.598 150 0.0179	1N 2O	9.0 16.0 0.0	107.790 25.000 132.790	27.672 0.0 2.377			Vel = 4.14	
406 to 406A	27.53 53.44	1.598 150 0.0683	2N	18.0 0.0 0.0	52.210 18.000 70.210	30.049 0.0 4.797			Vel = 8.55	
406A to 416	0.0 53.44	1.682 120 0.0804	2I 1J 1T	9.9 9.9 9.9	13.290 29.700 42.990	34.846 0.0 3.458			Vel = 7.72	

# Final Calculations - Standard

Residential Fire Protection  
MOTHERHOUSE SENIOR HOUSING

Page 6  
Date 7/27/2017

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
416	0.0	3.26	1F	4.032	3.000	38.304				
to		120	1S	21.503	38.975	0.0				
601	53.44	0.0032	1B	13.44	41.975	0.135		Vel =	2.05	
601	0.0	4.26		0.0	11.340	38.439				
to		120		0.0	0.0	4.911				
602	53.44	0.0009		0.0	11.340	0.010		Vel =	1.20	
602	0.0	4.26		0.0	12.080	43.360				
to		120		0.0	0.0	5.232				
603	53.44	0.0008		0.0	12.080	0.010		Vel =	1.20	
603	0.0	4.26	1J	21.067	12.580	48.602				
to		120		0.0	21.067	5.232				
604	53.44	0.0009		0.0	33.647	0.030		Vel =	1.20	
604	0.0	4.26	4I	36.868	20.170	53.864				
to		120		0.0	36.868	0.217				
605	53.44	0.0009		0.0	57.038	0.049		Vel =	1.20	
605	0.0	4.026	2F	8.0	14.000	54.130				
to		120	1E	10.0	18.000	1.447				
TOR	53.44	0.0011		0.0	32.000	0.036		Vel =	1.35	
TOR	0.0	4.026	1A	17.0	3.670	55.613				
to		120	1G	2.0	39.000	1.585				
HDR	53.44	0.0011	1T	20.0	42.670	0.049		Vel =	1.35	
HDR	0.0	7.981	1S	45.0	11.000	57.247				
to		120	1E	18.0	63.000	0.650				
6UG	53.44	0.0		0.0	74.000	0.003		Vel =	0.34	
6UG	0.0	6.16	1L	12.911	180.000	57.900				
to		140	1G	4.304	60.252	-1.984				
TEST	53.44	0.0001	1T	43.037	240.252	0.026		Vel =	0.58	
	100.00							Qa =	100.00	
	153.44					55.942		K Factor =	20.51	