

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
946-3473

Job Name : MOTHERHOUSE SENIOR HOUSING
Building : WOOD FRAMED
Location : 5TH FLOOR- APARTMENT UNIT (AREA #3)
System : 1
Contract : C17011
Data File : MOTHERHOUSE-5TH FLR-UNIT #2.WXF

Hydraulic Design Information Sheet

Name - MOTHER SENIOR HOUSING Date - 7/27/2017
 Location - 5TH FLOOR- APARTMENT UNIT (AREA #3)
 Building - WOOD FRAMED System No. - 1
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C17011
 Calculated By - T. PRAY Drawing No. - 5 OF 5
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 9'-0"
 Occupancy - RESIDENTIAL

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other RESIDENTIAL SPRINKLERS

T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - 4 SPRK'S System Type Sprinkler/Nozzle
 Density - .0508 (X) Wet Make VIKING
 D Area Per Sprinkler - 256 () Dry Model VK486
 E Elevation at Highest Outlet - 173.75 () Deluge Size 7/16"
 S Hose Allowance - Inside - () Preaction K-Factor 4.0
 I Rack Sprinkler Allowance - () Other Temp.Rat.155
 G Hose Allowance - Outside - 100

N Note

Calculation Flow Required - 52.57 Press Required - 51.97 AT BOR
 Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 6/2/2017 Cap. -
 T Time of Test - 6:30 AM Rated Cap.- Elev.-
 E Static Press - 58 @ Press -
 R Residual Press - 56 Elev. - Well
 Flow - 1061 Proof Flow
 S Elevation - 122

U Location - HYDRANTS ARE LOCATED ON STEVENS AVE, SEE PLOT PLAN

P Source of Information - PORTLAND WATER DISTRICT

C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf

O C
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING


Page 2
Date 7/27/2017

City Water Supply:

C1 - Static Pressure : 58
C2 - Residual Pressure: 56
C2 - Residual Flow : 1061

Demand:

D1 - Elevation : 22.413
D2 - System Flow : 52.571
D2 - System Pressure : 50.666
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 152.571
Safety Margin : 7.279



Fittings Used Summary

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 3
Date 7/27/2017

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
A	Generic Alarm Valve	0	0	0	0	0	0	7.7	21.5	0	17	17	27	29	0	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40	
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130	
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	

Pressure / Flow Summary - STANDARD

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 4
Date 7/27/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
10A	171.0	4	10.7	na	13.08	0.0508	256	10.6
11A	173.75	4	10.6	na	13.02	0.0508	256	10.6
509	173.25		11.29	na				
12A	173.75	4	10.75	na	13.11	0.0508	256	10.6
510	173.25		11.46	na				
13A	173.75	4	11.14	na	13.35	0.0508	256	10.6
511	173.75		11.6	na				
512	173.25		12.12	na				
513	173.25		16.31	na				
514	173.25		16.62	na				
515	173.25		28.08	na				
600	173.25		28.25	na				
601	161.92		33.17	na				
602	150.58		38.09	na				
603	138.5		43.33	na				
604	126.42		48.59	na				
605	125.92		48.86	na				
TOR	122.58		50.34	na				
HDR	118.92		51.97	na				
6UG	117.42		52.62	na				
TEST	122.0		50.67	na	100.0			

The maximum velocity is 7.59 and it occurs in the pipe between nodes 511 and 512

Final Calculations - Hazen-Williams

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 5
Date 7/27/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
10A to 509	13.08 13.08	1.049 120 0.0593	2T 3E	10.0 6.0 0.0	10.330 16.000 26.330	10.699 -0.974 1.562			K Factor = 4.00	
	0.0 13.08						11.287		K Factor = 3.89	
11A to 509	13.02 13.02	1.049 120 0.0588	2E	4.0 0.0 0.0	4.000 4.000 8.000	10.600 0.217 0.470			K Factor = 4.00	
509 to 510	13.09 26.11	1.38 120 0.0560		0.0 0.0 0.0	3.000 0.0 3.000	11.287 0.0 0.168			Vel = 4.83	
	0.0 26.11						11.455		K Factor = 7.71	
12A to 510	13.11 13.11	1.049 120 0.0595	1E 1T	2.0 5.0 0.0	1.250 7.000 8.250	10.747 0.217 0.491			K Factor = 4.00	
510 to 511	26.11 39.22	1.61 120 0.0563		0.0 0.0 0.0	6.375 0.0 6.375	11.455 -0.217 0.359			Vel = 4.87	
	0.0 39.22						11.597		K Factor = 11.52	
13A to 511	13.35 13.35	1.097 120 0.0495	1E 1T	2.487 6.217 0.0	0.500 8.704 9.204	11.141 0.0 0.456			K Factor = 4.00	
511 to 512	39.22 52.57	1.682 120 0.0778		0.0 0.0 0.0	3.960 0.0 3.960	11.597 0.217 0.308			Vel = 4.53	
512 to 513	-25.58 26.99	1.442 120 0.0481	3I 2J	11.148 14.864 0.0	61.010 26.012 87.022	12.122 0.0 4.186			Vel = 7.59	
513 to 514	0.0 26.99	1.442 120 0.0480		0.0 0.0 0.0	6.460 0.0 6.460	16.308 0.0 0.310			Vel = 5.30	
	0.0 26.99						16.618		K Factor = 6.62	
512 to 514	25.59 25.59	1.442 120 0.0436	4E 3T	14.864 22.296 0.0	66.000 37.160 103.160	12.122 0.0 4.496			Vel = 5.03	
514 to 515	26.98 52.57	1.682 120 0.0780	4T	39.599 0.0 0.0	107.290 39.599 146.889	16.618 0.0 11.462			Vel = 7.59	
515 to 600	0.0 52.57	3.26 120 0.0031	1Z 1S 1G	9.408 21.503 1.344	3.000 52.414 55.414	28.080 0.0 0.172			Vel = 2.02	
			1T	20.159						
600 to 601	0.0 52.57	4.26 120 0.0009		0.0 0.0 0.0	11.330 0.0 11.330	28.252 4.907 0.010			Vel = 1.18	

Final Calculations - Standard

Residential Fire Protection
MOTHERHOUSE SENIOR HOUSING

Page 6
Date 7/27/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
601	0.0	4.26		11.340		33.169			
to		120		0.0		4.911			
602	52.57	0.0009		11.340		0.010	Vel =	1.18	
602	0.0	4.26		12.080		38.090			
to		120		0.0		5.232			
603	52.57	0.0008		12.080		0.010	Vel =	1.18	
603	0.0	4.26	1J	21.067		12.580			
to		120		0.0		21.067			
604	52.57	0.0008		0.0		33.647	Vel =	1.18	
604	0.0	4.26	4I	36.868		20.170			
to		120		0.0		36.868			
605	52.57	0.0008		0.0		57.038	Vel =	1.18	
605	0.0	4.026	2F	8.0		14.000			
to		120	1E	10.0		18.000			
TOR	52.57	0.0011		0.0		32.000	Vel =	1.32	
TOR	0.0	4.026	1A	17.0		3.670			
to		120	1G	2.0		39.000			
HDR	52.57	0.0011	1T	20.0		42.670	Vel =	1.32	
HDR	0.0	7.981	1S	45.0		11.000			
to		120	1E	18.0		63.000			
6UG	52.57	0.0		0.0		74.000	Vel =	0.34	
6UG	0.0	6.16	1L	12.911		180.000			
to		140	1G	4.304		60.252			
TEST	52.57	0.0001	1T	43.037		240.252	Vel =	0.57	
	100.00						Qa =	100.00	
	152.57					50.666	K Factor =	21.43	