

**CAFETERIA ROOF FRAMING PLAN NOTES:**

1. ALL ROOF FRAMING SHALL BE SHOWN TO THE DEPTH OF THE JOIST'S BEARING SEAT UNLESS OTHERWISE NOTED. SEE SECTIONS.
2. TOP OF STEEL AS SCHEDULED BELOW, OR AS NOTED IN SECTIONS.
- 2A. 1. T.O.S. = 72'-10"
- 2B. 1. T.O.S. = 72'-10"
- 2C. 1. T.O.S. = 64'-6 1/2"
3. SPAN DIRECTION OF METAL DECK CONSTRUCTION INDICATED AS FOLLOWS:
- 3A. TYPE "B" 18 GAGE 1/2" DEEP (TYPE "B") METAL ROOF DECK.
- 3B. TYPE "B" 18 GAGE 1/2" DEEP (TYPE "B") METAL ROOF DECK.
- 3C. TYPE "B" 18 GAGE 1/2" DEEP (TYPE "B") METAL ROOF DECK.
4. MOMENT CONNECTIONS INDICATED AS FOLLOWS:
- 4.1. FIELD WELDED BEAM TO COLUMN CONNECTION PART OF THE LATERAL FORCE RESISTING SYSTEM. SEE TYPICAL DETAIL FOR DETAILS.
- 4.2. FIELD & SHOP WELDED OUTRIGGER CONNECTION TO RESIST GRAVITY FORCES ONLY. SEE SECTIONS.
- 4.3. INDICATES AXIAL THRU FORCE CONNECTION. SEE TYPICAL DETAIL ON S-200.
5. ANGLE INDICATES CONTINUOUS LATERAL SUPPORT OF BEAM OR FIELD WELDED TO THE TOP OF JOIST BEARINGS FOR PARAPET WALL ANCHORAGE. SEE SECTIONS AND DETAILS.
6. ALL ROOF DECK OPENINGS MAY NOT BE SHOWN. PENETRATIONS AND MAY BE FITTED IN THE FIELD PER TYPICAL DETAILS. SEE SECTIONS AND DETAILS. ALL DECK SHOP DRAWINGS FOR APPROVAL BY STEEL AND METAL CONTRACTOR SHALL REFER TO ARCH. AND MEP DRAWINGS FOR SCOPE (INCL. SIZES, LOCATIONS, QUANTITIES) AND INCLUDE THIS WORK IN THEIR BID.
7. INDICATES STEPPED CAST-IN-PLACE CONCRETE CURB FOR BRICK VENEER.

