



331 MP

# Portland Fire Department Monthly School Inspection

Name: OCEAN AVE	Address: 150 OCEAN AVE
Principal: DR COURSEY	Emergency Contact: DOUG SHERRWOOD
Date of Inspection 9/19/12	Inspector: CAPT. CANNON
	Time In: 1330      Time Out:

Fire Drills Conducted— Yes  No  Date of Last Drill 8/9/14

**EXITS:**

Exit/Escapes clear of obstructions  
Exit signs & Emergency Lighting in  
Proper order

Pass  Fail  Notes: \_\_\_\_\_  
Pass  Fail  Notes: \_\_\_\_\_

**Fire Alarm System**

Panel clear, accessible, operational

Pass  Fail  Notes: \_\_\_\_\_

**Fire Extinguishers**

Extinguishers full and tagged annually.

Extinguishers accessible

Pass  Fail  Notes: \_\_\_\_\_  
Pass  Fail  Notes: \_\_\_\_\_

**Heating System**

Boiler Room clear of all combustibles

Boiler Room properly rated/protected

Pass  Fail  Notes: \_\_\_\_\_  
Pass  Fail  Notes: \_\_\_\_\_

**Electrical System**

Extension cord use vs. permanent

Electrical Panels clear & accessible

Electrical Circuits clearly identified

Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_  
Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_  
Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_

**Sprinkler System**

Sprinkler heads >18" Clearance

Sprinkler Room & FDC Labeled & open

Spare heads and wrench supplied

Sprinkler system tagged insp. Date

Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_  
Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_  
Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_  
Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_

**House Keeping**

Furnishings & Decorations Flame Resistant

Art work displayed <20% wall area

Housekeeping organized for safety

Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_  
Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_  
Pass  Fail: \_\_\_\_\_ Notes: \_\_\_\_\_

**Additional Safety Concerns:**