



**Portland Fire Department**

6/6/2019

PETER D BORELLI  
47 IRVING ST  
PORTLAND, ME 04103  
jessrborelli@gmail.com

PETER D BORELLI  
47 IRVING ST  
PORTLAND, ME 04103  
jessrborelli@gmail.com

CERTIFIED MAIL

RE: 47 IRVING ST  
PORTLAND, ME

138 A021001

Page 1 of 2

**NOTICE OF VIOLATION  
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 7/18/2017 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

**A reinspection of your property will take place on 7/9/2019 11:00:00AM .**

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan  
Fire Prevention Bureau  
City of Portland

### NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
PFD Rules, 4.6	Unit or suite numbers must be clearly marked on doors, with the first numeral of each residential unit being the floor designation.	Apartments need to be numbered.	7/25/2017
NFPA 101-9.1.2; NFPA 70	All electrical equipment must comply with the National Electric Code.	exposed wiring in basement	8/17/2017
NFPA 101-9.1.2; NFPA 70	All electrical equipment must comply with the National Electric Code.	Missing box cover in basement	8/17/2017
Portland Code Ch. 10	Buildings must comply with Ch. 10 of the Portland Code of Ordinances.	Excessive/disorderly Storage basement	8/17/2017