


City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716



| | | |
|----------------------|-----------------------------------|---------------------|
| Permit No: 01-194 | Issue Date: SEP 24 2001 | CBL: 139 B007001 |
|----------------------|-----------------------------------|---------------------|

| | | | |
|--|--|---------------------------------------|---------------------|
| Location of Construction: 56 Mackworth St | Owner Name: Adams Ann E & | Owner Address: 56 Mackworth St | Phone: 74.6665 |
| Business Name: | Contractor Name: no contractor/self | Contractor Address: n/a n/a | Phone: |
| Lessee/Buyer's Name | Phone: | Permit Type: Additions - Dwellings | Zone: R-3 |

| | | | | |
|--|---|--|---|--------------------|
| Past Use: single family | Proposed Use: single family with 12' x 12' deck on rear of house | Permit Fee: \$36.00 | Cost of Work: \$1,163.00 | CEO District: 2 |
| Proposed Project Description: 12' x 12' deck on rear of house | | FIRE DEPT: <input type="checkbox"/> Approved <input type="checkbox"/> Denied <i>N/A</i> | INSPECTION: Use Group: R-3 Type: SB BUG 1999 | |
| | | Signature: | Signature: <i>T. [unclear]</i> | |

| | | |
|---|--|---------------------------------|
| PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) | | |
| Action: <input type="checkbox"/> Approved | <input type="checkbox"/> Approved w/Conditions | <input type="checkbox"/> Denied |
| Signature: | <i>N/A</i> | Date: |

| | | | | |
|-------------------------|---------------------------------|------------------------|--|--|
| Permit Taken By: dgc | Date Applied For: 09/24/2001 | Zoning Approval | | |
|-------------------------|---------------------------------|------------------------|--|--|

| | | | |
|---|--|--|--|
| <p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p> | Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: 9/24/01 | Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: 9/24/01 | Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: 9/24/01 |
|---|--|--|--|

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

| | | | |
|---|---------|------|-------|
| SIGNATURE OF APPLICANT | ADDRESS | DATE | PHONE |
| RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE | | DATE | PHONE |

0/9/01 Pre-con w/ Dan Boutin - he has to work out details of Sauna placement per plan Review. Stairs are a kit from Hancock - reviewed code requirements
May put off until Spring JB

1/13/01 - Checked setbacks - all conforming - checked sonar tube depth - all at 4ft - OK to proceed.

Tom M.

7/19/02 - Checked deck for final - no numerals -

risers open on steps - guaranteed ht. is 36 inches on bottom step only - which is 34 inches.

Tom M.