Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 04/09/15

15,000 BTU/hr Mitsubishi MSZ FH15 Indoor Unit
Mounted to wall framing in the main living room and facing towards the front of the house.
Weight of unit is 29 lbs.

15,000 BTU/hr Mitsubishi MUZ FH15 Outdoor Unit
Installed on wall-mounted bracket fastened to the concrete foundation, on eastern gable end of home. Weight of unit is 124 lbs.

Notes:
Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

ReVision Energy	HVAC Equipment Layout				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	Montgomery, Judy 53 Parsons Road, Portland ME 04103				
	DATE 4/6/2015	DRAWN BY Luke Brostek	PAGE 1 of 1	DWG# 1	Rev. 0