

All State Fire Equipment

A Division of the Allstate Family of Fire Suppression Companies

20C Del Carmine Street

Wakefield, MA 01880

781-224-1001

Pre-Engineered System Inspection Report

Date of Service: 12/7/16 Time: _____ AM PM

Annual / Semi-Annual / Recharge / Installation / Renovation (Circle one)

Customer / Location

Name: TiPO

Address: 182 Ocean Ave

City, ST, Zip: Portland Me.

Owner / Manager: Chris

Phone: 416

System Information:

Make: Ansol

Model: R-102

Size: 3ga

Control Head Type / Location: OFM / Co-Signet

Location of Gas Valve:

- 1 System interlocked with building fire alarm
2 All tamper seals intact. No evidence of tampering
3 All appliances properly covered w/ correct nozzles
4 Duct(s) & plenum properly covered w/ correct nozzles
5 Filters in place at time of inspection
6 Pressure gauge in acceptable range
7 Checked cartridge weight
8 Cylinder within hydrotest date Due 2020
9 Inspected cylinder & mount
10 Checked operation of detection line
11 # of fusible links 360° 2 450° 1 500° other()
12 Replaced fusible links 2016

Yes No N/A

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

- 13 Checked operation of manual release
14 Checked operation of micro-switch
15 Checked operation of gas valve (MECH / ELEC)
16 Piping / conduit securely braced
17 Nozzles cleaned
18 Proper nozzle caps/covers in place Qty _____
19 System operational & armed
20 Fan warning sign on hood
21 K-Class fire extinguisher in cooking area
22 Allstate Fire Equipment sticker on Automan
23 Service & certification tag on system
24 System meets U.L. 300 Standards

Yes No N/A

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Cooking Appliances (left to right) Oven 24" 4BR Range / 12" x 24" griddle under

Salamander Broiler, 14" x 15" fryer w/ 9" drip board

Safety Notice: Non-compliant systems may fail to extinguish/suppress a fire. Below are non-compliant conditions which require immediate attention. All State Fire Equipment assumes no responsibility for system performance if these conditions are not corrected and/or verified by an authorized agent of All State Fire Equipment.

Comments / Non-Compliance:

All State Fire Equipment Agent: Paul Dahl

Date: 12/7/16

Customer's Authorized Agent: _____

Date: _____