

LOCUS MAP: 98 WELLINGTON STREET

1. DIMENSIONS ARE TO FACE OF FRAMING, FOUNDATION & THE CENTERLINE OF INTERIOR WALLS UNLESS NOTED OTHERWISE.

2. DO NOT SCALE DRAWINGS - WORK FROM DIMENSIONS ONLY.

3. IF THIS PROJECT INVOLVES AN EXISTING STRUCTURE. DIMENSIONS SHOWN ON THE DRAWING ARE BELIEVED TO BE ACCURATE, BUT CANNOT BE GUARANTEED. THE GENERAL CONTRACTOR SHALL MEASURE AND VERIFY ALL DIMENSIONS IN FIELD PRIOR TO FABRICATION AND CONSTRUCTION.

4. ALL WORK SHALL COMPLY WITH APPLICABLE NATIONAL, STATE & LOCAL CODES.

5. G. CONTRACTOR RESPONSIBLE FOR OBTAINING REQUIRED PERMITS.

6. CONTRACTOR SHALL PROPERLY DISPOSE OF ALL CONSTRUCTION DEBRIS OFF-SITE. 7. EXTERIOR PAVING AND GRADE SHALL SLOPE AWAY FROM BUILDING TO DRAINAGE WAYS.

8. NOTIFY OWNER/STRUCTURAL ENGINEER BEFORE PENETRATING OR MODIFYING JOISTS, BEAMS, COLUMNS OR OTHER STURCUTRAL MEMBERS.

10. INSTALL WINDOWS & FLASHING FOLLOWING MANUFACTURERS INSTRUCTIONS WITH STICK-ON FLASHING TO PROVIDE WATERPROOF SEAL 11. PROVIDE A CONTINUOUS BEAD OF SEALANT IN ALL JOINTS IN BUILDING, INCLUDING: ENVELOPE, PERIMETER, ISOLATION JOINTS, COLUMN PIPE, ALL

PENETRATIONS AND CONDITIONS SO THAT NO MOISTURE, VAPOR OR GAS MAY PASS THROUGH STRUCTURE. 12. THE ROOF BOTTOM EDGE 3'-0" WIDE SHALL HAVE A WATERPROOF MEMBRANE LIKE "ICE & WATER SHIELD."

13. PROVIDE DOUBLE STUDS AT EACH SIDE OF NORTH WINDOW FRAMES. 14. PROVIDE PRE-MOULDED ISOLATION STRIP BETWEEN ALL FOUNDATION WALLS AND CONCRETE SLAB.

15. WOOD BLOCKING IN CONTACT WITH CONCRETE OR STONE TO BE PRESERVATIVE TREATED BY PRESSURE PROCESS. SEAL CUTS IN "PT" WOOD WITH FIELD APPLIED PRESERVATIVE. USE STAINLESS STEEL FASTENERS.

16. GENERAL CONTRACTOR SHALL COORDINATE ALL UTILITIES.

17. HEATING SYSTEM TO BE PROFORMANCE BASED, DESIGN BY MECHANICAL CONTRACTOR. OWNER TO APPROVE BEFORE PURCHASING. 18. ELECTRICAL LIGHTS & OUTLETS TO BE INSTALLED BY CERTIFIED ELECTRICIAN. OWNER TO APPROVE BEFORE PURCHASING.

19. CONTRACTOR TO BRING TO THE ATTENTION OF THE ARCHITECT ANY CONDITION DIFFERENT FROM THOSE SHOWN ON THE DRAWINGS, AND SHALL BRING TO THE ATTENTION OF THE ARCHITECT ANY CONDITION THAT PREVENT CONTRACTOR'S COMPLETION OF THE WORK AS SHOWN ON THE DRAWINGS.

20. TAPE ALL GYPSUM SEAMS AND PAINT PER FINISH SCHEDULE.

21. PROVIDE PAPERLESS, MOISTURE RESISTANT GWB IN BATHROOMS, TYP. 22. SEAL ALL OUTLETS & PENETRATIONS IN VAPOR RETARDER W/TAPE COMPLIANT W/VAPOR RETARDER MANUFACTURER.

23. CONTRACTOR TO CONDUCT VISUAL INSPECTION OF SHEATHING TO SPOT AND SEAL PENETRATIONS, INCLUDING NAIL HEAD PENETRATIONS IN VAPOR

24. USE SPRAY FOAM INSULATION TO SEAL AIR GAPS IN HARD-TO-REACH PLACES THAT ARE UNLIKELY TO BE FILLED DURING APPLICATION OF INSULATION. 25. PROVIDE METAL DRIP EDGES ON ALL ROOF EVES, TYP. AND METAL FLASHING W/DRIP EDGE ON ALL WINDOWS, TYP.

WOOD FRAMING NOTES

1. STRUCTURAL LUMBER:

-NO. 2 SPRUCE-PINE-FIR OR BETTER. 19% MAX MOISTURE CONTENT. -PRESSURE TREATED LUMBER: NO. 2 OR BETTER SOUTHERN YELLOW PINE.

-LAMINATED VENEER LUMBER (LVL): EQUIVALENT TO VERSA-LAM 2.0 3100 BY BOISE ENGINEERED PRODUCTS. LUMBER SIZES SHOWN ARE NOMINAL SIZES.

2. DESIGN CODE: NATIONAL DESIGN SPECIFICATIONS FOR WOOD CONSTRUCTION BY THE AMERICAN FOREST & PAPER ASSOCATION.

3. FASTENERS: COMPLY WITH RECOMMENDED FASTENING SCHEDULE OF THE 2009 INTERNATIONAL BUILDING CODE, UNLESS OTHERWISE SHOWN ON DRAWINGS. 4. NAILING REQUIREMENTS FOR PLYWOOD FLOOR DECKS, ROOF DECK AND SHEATHING: PROVIDE 8d COMMON NAILS FOR ROOF & WALLS, 8d ROSIN COATED RING SHANK NAILS FOR FLOORS AS FOLLOWS:

a. 6" O.C. ALONG ALL FLOOR PANEL EDGES

b. 12" O.C. ALONG INTERMEDIATE MEMBERS

5. SPIKE TOGETHER ALL FRAMING MEMBERES WHICH ARE BUILT-UP USING 2 ROWS OF 16d NAILS @ 12" O.C. STAGGERED. 6. PROVIDE GALVANIZED METAL JOIST HANGERS AT FLUSH-FRAMED CONNECTIONS. IF SIZES ARE NOT SHOWN ON PLANS FOR SINGLE 2x'S PROVIDE HANGERS

EQUAL TO SIMPSON U210 OR LU210. 7. PROVIDE GALVANIZED METAL RAFTER TIES EQUAL TO SIMPSON H 2.5 BETWEEN RAFTERS AND SUPPORTING MEMBERS, UNLESS OTHERWISE SHOWN.

8. PROVIDE MINIMUM OF (2) 2x10 HEADRES OVER OPENINGS 4'-0" OR WIDER IN BEARING WALLS. PROVIDE (2) 2x8 MINIMUM IN OPENINGS LESS THAN 4'-0", UNLESS

9. PROVIDE DOUBLE TOP PLATE IN ALL EXTERIOR WALLS AND ALL BEARING WALLS. STAGGER TOP PLACE SPLICES IN EXTEIOR WALLS 4'-0" AND PROVIDE AT LEAST

8-16d NAILS EACH SIDE OF SPLICE. 10. PROVIDE PRESSURE TREATED LUMBER FOR ALL LUMBER IN CONTACT WITH MASONRY OR CONCRETE.

11. PROVIDE MIN. OF (2) 2x STUDS AT ENDS OF ALL BUILT-UP BEAMS OR HEADERS UNLESS SHOWN OTHERWISE.

12. WHERE POST CAPS OR BASES ARE NOT SHOWN ON DRAWINGS, PROVIDE THE FOLLOWING: -POST FRAMES UNDER OR OVER BEAMS: SIMPSON LPC SERIES POST CAPS FOR CAPS & BASES.

-POST FRAMING ONTO SILLS: SIMPSON BOC 60 OR BC 40 BASES. 13. ROOF, FLOOR AND WALL SHEATHING. APA RATED SHEATHING, EXPOSURE 1 OR STRUCTURAL I OR II RATED SHEATHING, EXPOSURE 1.

a. ROOF: SPAN RATING 32/16 MIN. THICKNESS 19/32" b. FLOORS: SPAN RATING 32/16" MIN. THICKNESS 23/32"

c. WALLS: MIN. THICKNESS 15/32" 14. PROVIDE FULL-DEPTH BLOCKING AT ENDS AND INTERIOR SUPPORTS OF ALL JOISTS AND RAFTERS WHERE JOISTS AND RAFTERS FRAME OVER SUPPORTS.

15. PROVIDE 1/2" DIAMETER ANCHOR BOLTS WITH MINIMUM 12" EMBEDMENT INTO FOUNDATION FOR ALL SILL PLATES. PROVIDE MINIMUM OF 2 BOLTS PER SECTION OF PLATE. ONE BOLT AT 12" FROM END OF EACH SECTION OF PLATE, WITH INTERMEDIATE BOLTS. PLACED NOT MORE THAN 6'-0" ON CENTER.

16. PROVIDE SOLID BLOCKING @ ENDS OF ALL WOOD BEAMS TO PREVENT ROTATION OF BEAM.

17. CONNECTIONS AT PRESSURE TREATED (P.T. OR PT) WOOD: a. PROVIDE EQUIVALENT TO Z-MAX OR HOT DIPPED GALVANIZED CONNECTORS BY SIMPSON STRONG-TIE W/STAINLESS

STEEL FASTENERS OR FASTENERS GALVANIZED PER ASTM A153

b. PROVIDE PROTECTION MEMBRANE AT LOCATIONS SHOWN ON THE DRAWINGS AND WHERE Z-MAX PROTECTION MEMBRANE= GRACE VYCOR DECK PROTECTOR.

View Name ' 1/8" = 1'-0"

Room name Name \_ ROOM NAME, NUMBER & SF **ELEVATION** Elevation 101 150 SF DOOR TAG SPOT ELEVATION WALL TAG WINDOW TAG CENTERLINE NORTH SYMBOL


AFF | Above finish floor DWG | Drawing EL | Elevation GA | Gauge GWB | Gypsum wall board EQ | Equal GPF | Gallons per flush (toilets) FE | Fire extinguisher HVAC | Heating, ventilation and air conditioning LM | Lumens MIN | Minimum NTS | Not to scale PSI or PSF | Pounds per square inch or pounds per square foot, pressure or strenath UNO | Unless noted otherwise R-Value | Thermal resistance RCP | Reflected ceiling plan SHG | Solar Heat Gain SF | Square foot SIM | Similar STRUCT. | Structural T.O. | Top of

ADA | Americans with disabilities act

TYP. | Typical

VIF | Verify in field

VT | Visual transmittance, a measurement of transparency/translucency WC | Water closet, otherwise known as a bathroom



50' - 0"

A Site Plan with First Floor Underlay

Sheet List 1.1 PLANS & INTERIOR ELEVATIONS -2.1 ELEVATIONS

ADDRESS | 98 WELLINGTON STREET CBL | 141 C027001 AREA | 5,250 SF LOT ZONE | R-3 USE | SINGLE FAMILY BUILT | 1943 AREA: 846 SF


APPLICABLE BUILDING CODES IRC 2009 IEBC 2009 NFPA 101 NFPA 1 2009

PROJECT DESCRIPTION
LEVEL-III ALTERATION OF EXISTING SINGLE-FAMILY RESIDENCE.UNSPRINKLERED. PROJECT TO INCLUDE NEW CABINETS AND BUILT-IN STORAGE IN KITCHEN. NEW TUB SURROUND, EXHAUST FAN AND FLOORING IN BATHROOM. MODIFICATION ENTIRELY WITHIN EXISTING FOOTPRINT, NO ADDITIONS. NEW CLOSETS AND EGRESS WINDOWS IN BEDROOMS.

ZONING -STREET FRONTAGE: 50'-0" -MIN. LOT WIDTH: 65'-0" -FRONT SETBACK | 25'-0" OR AVERAGE OF ADJACENT STRUCTURES -BACK SETBACK | 25'-0" -SIDE SETBACK | 8'-0"

MAX. LOT COVERAGE | 35% MAX. MAXIMUM HEIGHT | 35'-0"

INSULATION VALUES REQ. PER ICC 2009 TABLE 402.1.1 CLIMATE ZONE | 6A CEILINGS | R-49 WALLS | R-20 SKYLIGHTS | 0.6 U-FACTOR FENESTRATIONS | .35 U-FACTOR BAEMENT WALL 15/19 FLOOR | R-30



98 WELLINGTON

INTERIOR RENOVATION OF SINGLE-FAMILY STRUCTURE - NO SITE WORK, OR ADDITION

TROY AND SALLY MOON 98 WELLINGTON ROAD PORTLAND, ME 04103 SALLY: lunabride@gmail.com TROY: portcitymoon@gmail.com



TRACIE REED, ARCHITECT NCARB, AIA, LEED AP BD+C traciereed@dextrouscreative.com 207.409.0459 (cell)

PROJECT TEAM

GENERAL CONTRACTOR EAST END CARPENTRY

egibbs@maine.rr.com 207.232.6312 (CELL)

Description

17-20 98 WELLINGTO Project number STREE 02.21.18 Drawn by Checked by TJR

TITLE

As indicated