


**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: <b>Glecker Rd. lots 14, 15 &amp; 48</b>		Owner: <b>Bill Morrell &amp; LeFevre Builders</b>	Phone: <b>650-5444 -878-3900</b>	Permit No: <b>000642</b>
Owner Address: <b>72 Auburn St., Portland</b>		Lessee/Buyer's Name: <b>N/A</b>	Phone:	Business Name:
Contractor Name: <b>Morrell &amp; LeFevre ***</b>		Address: <b>72 Auburn St., Portland ***</b>		<div style="border: 2px solid black; padding: 5px; text-align: center;"> <b>PERMIT ISSUED</b>    <b>CITY OF PORTLAND</b>                  Zone: <b>B-3</b> CBL: <b>141-E-14, 15, 48</b>                  Zoning Approval:             </div>
Past Use: <b>vacant</b>	Proposed Use: <b>single family home</b>	COST OF WORK: <b>\$ 170,000</b>	PERMIT FEE: <b>\$ 1,344.00</b>	
		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: <b>A-3</b> Type: <b>5A</b> Signature: <i>[Signature]</i>	
Proposed Project Description: <b>build a single family home</b>		Signature: _____ Date: _____		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____
Permit Taken By: <b>KA</b>	Date Applied For: <b>May 24, 2000 JF</b>			Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

**PERMIT ISSUED WITH REQUIREMENTS**

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT	ADDRESS:	DATE: <b>May 24, 2000</b>	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

**PERMIT ISSUED WITH REQUIREMENTS**

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 79 GLECKLER RD		Owner: MORRELL & LEFEVRE	Phone: 650-5444	Permit No: 001387
Owner Address: SAA	Lessee/Buyer's Name:	Phone:	BusinessName:	Permit Issued:  DEC 8 2000
Contractor Name: *** M&L BUILDERS 72 AUBURN ST PORTLAND ME ****		Address: Phone:		
Past Use: SINGLE FAMILY	Proposed Use: SAME	COST OF WORK: \$ 3,500	PERMIT FEE: \$ 48.00	Zoning Approval: ok Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision 12/7/00 <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group A-3 Type 5B 000499 Signature: [Signature]	
Proposed Project Description:  AMEND 000642 ADD 2 SMALL LANDINGS OR DECKS AND STAIRS		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		
Permit Taken By: K	Date Applied For: DEC 6 2000			

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

**PERMIT ISSUED WITH REQUIREMENTS**

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

DEC 6 2000 K

SIGNATURE OF APPLICANT \_\_\_\_\_ ADDRESS: \_\_\_\_\_ DATE: \_\_\_\_\_ PHONE: \_\_\_\_\_

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE \_\_\_\_\_ PHONE: \_\_\_\_\_

**Zoning Appeal**

Variance  
 Miscellaneous  
 Conditional Use  
 Interpretation  
 Approved  
 Denied

**Historic Preservation**

Not in District or Landmark  
 Does Not Require Review  
 Requires Review

**Action:**

Approved  
 Approved with Conditions  
 Denied

Date: \_\_\_\_\_ [Signature]

**PERMIT ISSUED WITH REQUIREMENTS**  
CEO DISTRICT

COMMENTS

001387

141-1-1

12/11/00 OK For Co FO

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

COMMENTS

5/25/00 called Bill Morrell about moving the house forward so a better rear deck might be erected in the future - At this point set backs are OK

7/3/00 On Site with Bill Morrell hole dug - POC Con Expedited check wednesday for forums setback well within tolerances (DC)

7/13 - for Permit - OK

9/14 - Framing OK to Close DC

11/21 - Final - Vail railing inadequate (36"), Amend to include side entry and rear deck (DC)

12/5 Railings corrected to 42"

12/11 OK for POC see amendment (DC)

Inspection Record

Type

Date

Foundation: \_\_\_\_\_

Framing: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Final: \_\_\_\_\_

Other: \_\_\_\_\_

141 - V - 14

000647



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

000563

MAY 26 2000

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

141-F-041

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lots 1415+48 Glectler Rd Use of Building Residential Date 5/24/00  
Name and address of owner of appliance Morieil + LeFevre

Installer's name and address Atlantic HTG Co 133 Pride St  
Telephone \_\_\_\_\_

### Location of appliance:

- Basement
- Floor
- Attic
- Roof

### Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: Peerles

U.L. Approved  Yes  No

Will appliance be installed in accordance with the manufacture's installation instructions?  Yes  No

IF NO Explain: \_\_\_\_\_

### The Type of License of Installer:

- Master Plumber # \_\_\_\_\_
- Solid Fuel # \_\_\_\_\_
- Oil # 02768
- Gas # \_\_\_\_\_
- Other \_\_\_\_\_

### Type of Chimney:

Masonry Lined  Factory built \_\_\_\_\_

Metal  
Factory Built U.L. Listing # \_\_\_\_\_

Direct Vent  
Type \_\_\_\_\_ UL# \_\_\_\_\_

### Type of Fuel Tank

- Oil
- Gas

Size of Tank 330

Number of Tanks 1

Distance from Tank to Center of Flame 6' feet.

30.00

### Approved

Fire: 1407  
Ele.: \_\_\_\_\_  
Bldg.: A

### Approved with Conditions

- See attached letter or requirement

Signature of Installer \_\_\_\_\_

# ELECTRICAL PERMIT

## City of Portland, Me.



SF DC

Ⓟ

To the Chief Electrical Inspector, Portland Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 9-16-00

Permit # 710

CBL# 141-F-014

LOCATION: 79 Gledken Road. METER MAKE & # \_\_\_\_\_  
 CMP ACCOUNT # 441-166-3153-001 OWNER Claire Greenlaw Jr.  
 TENANT \_\_\_\_\_ PHONE # \_\_\_\_\_

**TOTAL EACH FEE**

Category	Item	Quantity	Unit Price	Total
OUTLETS	Receptacles	40		
	Switches	20		
	Smoke Detector	5	.20	1.00
FIXTURES	Incandescent	10		
	Fluorescent Strips		.20	2.00
SERVICES	Overhead	✓		
	Underground			
Temporary Service	Overhead			
	Underground			
METERS	(number of)	1	1.00	1.00
	MOTORS (number of)		2.00	
RESID/COM	Electric units		1.00	
HEATING	oil/gas units			
	Interior Exterior		5.00	
APPLIANCES	Ranges	✓	2.00	2.00
	Insta-Hot		2.00	
	Dryers	✓	2.00	2.00
	Compactors	✓	2.00	2.00
MISC. (number of)	Others (denote)		2.00	
	Air Cond/win		3.00	
	Air Cond/cent			
	HVAC	EMS		
	Signs		10.00	
	Alarms/res		5.00	
	Alarms/com		15.00	
	Heavy Duty(CRKT)		2.00	
	Circus/Carnv		25.00	
	Alterations		5.00	
	Fire Repairs		15.00	
	E Lights		1.00	
	E Generators		20.00	
	PANELS	Service		4.00
Remote				
TRANSFORMER	0-25 Kva		5.00	
	25-200 Kva		8.00	
	Over 200 Kva		10.00	
			TOTAL AMOUNT DUE	
			MINIMUM FEE/COMMERCIAL 45.00	
			MINIMUM FEE 35.00	47.00

INSPECTION: Will be ready \_\_\_\_\_ or will call \_\_\_\_\_

CONTRACTORS NAME P.A. Libby Electric MASTER LIC. # 03779  
 ADDRESS 36 Swobodeny Dr. So. Portland, Me. LIMITED LIC. # \_\_\_\_\_  
 TELEPHONE 799-0433

SIGNATURE OF CONTRACTOR Paul Libby  
 Pager 471-7707

# PLUMBING APPLICATION

Department of Human Sciences  
Division of Health Engineering

2141-F-014

## PROPERTY ADDRESS

Town or Plantation	Portland
Street Subdivision Lot #	110518 Gloucester Rd
Last: <i>MacNeil &amp; LaFoure</i>	First:
Applicant Name:	
Mailing Address of Owner/Applicant (If Different)	72 Auburn St Portland

PORTLAND 7304 TOWN COPY

Date Permit Issued: 15.24.00 \$9.00

*Samuel Hoffer* Local Plumbing Inspector Signature L.P.I.# 0124

# Double Fee Charged

### Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspectors to deny a Permit.

*William MacNeil*  
Signature of Owner/Applicant Date

### Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature Date Approved

## PERMITS INFORMATION

<b>This Application is for</b> 1. <input checked="" type="checkbox"/> NEW PLUMBING 2. <input type="checkbox"/> RELOCATED PLUMBING	<b>Type of Structure To Be Served:</b> 1. <input checked="" type="checkbox"/> SINGLE FAMILY DWELLING 2. <input type="checkbox"/> MODULAR OR MOBILE HOME 3. <input type="checkbox"/> MULTIPLE FAMILY DWELLING 4. <input type="checkbox"/> OTHER - SPECIFY _____	<b>Plumbing To Be Installed By:</b> 1. <input checked="" type="checkbox"/> MASTER PLUMBER 2. <input type="checkbox"/> OIL BURNERMAN 3. <input type="checkbox"/> MFG'D. HOUSING DEALER/MECHANIC 4. <input type="checkbox"/> PUBLIC UTILITY EMPLOYEE 5. <input type="checkbox"/> PROPERTY OWNER LICENSE # <u>9279</u>
---	--	---

Hook-Up & Piping Relocation Maximum of 1 Hook-Up	Number	Column 2 Type of Fixture	Number	Column 1 Type of Fixture
<b>OR</b> HOOK-UP: to an existing subsurface wastewater disposal system.  <b>OR</b> PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.	2	Hosebibb / Sillcock	1	Bathtub (and Shower)
		Floor Drain	1	Shower (Separate)
		Urinal	1	Sink
		Drinking Fountain	3	Wash Basin
		Indirect Waste	2	Water Closet (Toilet)
		Water Treatment Softener, Filter, etc.	1	Clothes Washer
		Grease / Oil Separator	1	Dish Washer
		Dental Cuspidor	1	Garbage Disposal
		Bidet	1	Laundry Tub
		Other: _____	1	Water Heater
<b>OR</b> TRANSFER FEE [\$6.00]		Fixtures (Subtotal) Column 2	12	
<b>SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE</b>				
			15	
				<b>Total Fixtures</b>
				<b>Fixture Fee</b>
				<b>Transfer Fee</b>
				<b>Hook-Up &amp; Relocation Fee</b>
				<b>Permit Fee (Total)</b>