Inspections Division
Date: 05/17/17

Above Ground Swimming Pool

Electrical Wiring Requirements per
Article 680 of The National Electrical
Code & Underwriters Laboratories Listing

3 Foot Long 12 Gauge Cord
3 Wire, 3 Prong
Flange Twist Lock Plug

Receptacle Box With A
Hubbell NO.2310 Receptacle
20A, 125 VAC, or Equivalent
Twist Lock Receptacle That
Meets Nema L5-2 Configuration

20 AMP 3 Prong
Twist Lock Plug End

Note: 1 Do Not Locate Receptacle Box Closer Than 5 FT from inside Pool Wall or Installation
Will not be in compliance with Article 680 of the N.E.C. Electrical Code nor will Filter & Pump hoses reach for Proper Installation.