



## Department of Permitting and Inspections

Air Velocity within the duct system .75 sp. 3000 cfm

Grease accumulation prevention system: \_\_\_\_\_

Cleanouts: High temp clean out in 90° and 45° elbows

Grease Duct enclosure: 3m 615' grease duct wrap

Exhaust Termination: Roof \_\_\_\_\_ Wall X

Fire Suppression System: Done By other

Exhaust fan mounting and clearance from the roof / wall or Combustibles:  
40" on radials and 18" away from building on off roof

Exhaust fan distance from property lines: 10'

Exhaust fan distance from other vents or openings: 10'

Exhaust fan distance from adjacent buildings: 10'

Exhaust fan height above adjoining grade: 16'

### 3. Hood Specs

Style of Hood: Canopy

Type of Filter: grease baffles

Height of filter above nearest cooking surface: 36"

Capacity of hood CFM: 3000 cfm

Make up Air system description and capacity:  
2400 cfm return into hood system well manted fan and duct  
into building with 24 gauge galv.