CITY OF PORTLAND FIRE PREVENTION BUREAU

380 Congress Street, Portland, Maine 04101 fireprevention@portlandmaine.gov (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

JOSEPH WOJCIK 211 FALMOUTH RD FALMOUTH ME 04105

December 7, 2017

Location: Trophy Shed	CBL	Inspection Date	
955 FOREST AVE	142 B003001	11/8/2017	
Inspector	Inspection Type	Status	
Bruce Cyr	FP Routine Inspection	Failed	

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 12/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101-40.2.4 MEANS OF EGRESS ; The number of means of egress shall comply with either 40.2.4.1.1 or 40.2.3.2.	
Rear Exit obstructed	
NFPA 101-7.9 EMERGENCY LIGHTING	
Units not functional	
1-4.4.6 SYSTEM DESIGN/INSTALLATION TO MEET NFPA STANDARDS; ANY FIRE PROTECTION SYSTEM, BUILDING SERVICE EQUIPMENT, FEATURE OF PROTECTION, OR SAFEGUARD PROVIDED TO ACHIEVE THE GOALS OF THIS CODE SHALL BE DESIGNED, INSTALLED, AND APPROVED IN ACCORDANCE WITH THE APPLICABLE CODES AND STANDARDS REFERENCED IN CHAPTER 2.	
There is an alarm panel to the right of the units main entrance. It does not appear to be powered, let alone operationsl	
NFPA 1-1.12.5.13 FIRE ALARM INSPECTION STICKER REQUIRED; Permits shall be issued by the AHJ and shall bear the name and signature of the AHJ or that of the AHJ's designated representative. In addition, the permit shall indicate the following: (1) Operation or activities for which the permit is issued (2) Address or location where the operation or activity is to be conducted (3) Name and address of the permittee (4) Permit number and date of issuance (5) Period of validity of the permit (6) Inspection requirements and other permit conditions No tag indicating system serviced and tested	
PORTLAND FIRE DEPARTMENT CHAPTER 10 SECTION 12 KNOX BOX REQUIRED; Knox Boxes are required for all buildings with fire alarm or suppression systems.	

Violation		Proposed Date of Completion
conducted, records for manua	IGUISHER INSPECTION TAG; Where manual inspections are il inspections shall be kept on a tag or label attached to the fire checklist maintained on file, or by an electronic method. The checked 2013	
malfunctions shall be correcte		
multiple detectors hanging by FINAL DATE OF COMPLETE		/ /
	. ,	//
FIRE PREVENTION BUREAU	U RE-INSPECTION OF COMPLETED VIOLATION(S)	//
_	ht to reject or modify any proposed plan of action, and may nical capacity to complete the proposed plan. Please contactation	-
understand that I must conte	ions listed within the timeframes provided. If I require add act the Fire Prevention Bureau <u>prior to the deadline</u> to requa's discretion to grant or deny.	
•	is my responsibility to schedule a reinspection of my prope o. My failure to schedule a reinspection shall be deemed ar nedied.	-
	agreement, I understand that I am liable for penalties pursules §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be	
Date	Responsible Party	
Date	Responsible Party	
SEEN AND AGREED		
Date	Fire Prevention Bureau	