

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

A HAUSMANN ASSOCIATES INC /Jason Young

Located at

1025 FOREST AVE (1037) Unit 5

PERMIT ID: 2013-02470

ISSUE DATE: 12/16/2013

CBL: 142 C001001

has permission to **Change of use from indoor golf to retail beverages & cigarettes) - fit up of space includes installation of non- load bearing walls for coolers, and related electrical** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Unit 5 - retail

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping
Electrical Close-in w/Fire & Draftstopping
Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-02470	Date Applied For: 11/04/2013	CBL: 142 C001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Unit 5 - retail	Proposed Project Description: Change of use from indoor golf to retail beverages & cigarettes) - f up of space includes installation of non- load bearing walls for coolers, and related electrical			
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 11/08/2013				
Note: Retail use for this sapce requires 18 parking spaces. Lease allows parking out front and in the rear. 43 spaces Ok to Issue: <input checked="" type="checkbox"/>				
Conditions: 1) Separate permits shall be required for any new signage.				
Dept: Building Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 12/16/2013				
Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions: 1) Separate Permits shall be required for any new signage. 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Craig Messinger Approval Date: 11/25/2013				
Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions: 1) Shall comply with 2009 NFPA 101 Chapter 37 Existing Mercantile Occupancy 2) Any and all exhistng violations to be corrected.				