

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

DAKOTA BEAR PROPERTIES LLC

Located at

135 WALTON ST (Unit F)

PERMIT ID: 2015-02016

ISSUE DATE: 10/20/2015

CBL: 142 I001001

has permission to **Change of Use - (Unit F) create two (2) individual growing spaces for a medical marijuana growing facility for individual patients. Connected to permit #2015-02013**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Unit F- medical marijuana cultivation facility

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing
Electrical - Commercial
Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-02016	Date Applied For: 08/18/2015	CBL: 142 I001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Medical Marijuana Growing Facility (Unit F)		Proposed Project Description: Change of Use - (Unit F) create two (2) individual growing spaces for a medical marijuana growing facility for individual patients. Connected to permit #2015-02013		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 09/29/2015	
Note: Connected to permit 2015-02013 which is creating the new egress area to the outside & Unit K.				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Separate permits shall be required for any new signage.				
2) All State Certifications shall be maintained and kept up to date. If State licensing fails, the use for cultivating marijuana will no longer be legal and would need to be removed as a use.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 10/16/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS	Status: Not Applicable	Reviewer: Benjamin Pearson	Approval Date: 08/26/2015	
Note:				Ok to Issue: <input type="checkbox"/>
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 10/19/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Any cutting and welding done will require a Hot Work Permit from Fire Department.				
2) Shall comply with NFPA 1, Chapter 16, Safeguards During building construction, alteration, and demolition operations.				
3) Shall comply with NFPA 101, Chapter 40, Industrial Occupancies.				
4) All outstanding code violations shall be corrected prior to final inspection.				
5) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
6) All construction shall comply with City Code Chapter 10.				