



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION  
84 HACKETT MILLS ROAD  
P.O. BOX 156  
POLAND, ME 04274  
207-998-2551

Job Name : NOKIAN TYRES WALTON STREET GRID 3  
Drawing : Unit C  
Location : 135 Walton Street Portland  
Remote Area : Grid #3  
Contract : 041415-2  
Data File : Grid 3 looped.WXF

Hydraulic Design Information Sheet

Name - Nokian Tyre Warehouse Date - 9-15-15  
 Location - 135 Walton Street Portland  
 Building - Unit C System No. - Grid #3  
 Contractor - High Tech Fire Protection Contract No. - 041415-2  
 Calculated By - Ed Poulin Drawing No. - FP-01  
 Construction: ( ) Combustible (X) Non-Combustible Ceiling Height - 18'  
 Occupancy - Chapter 18 Tire Storage up to 25' with ESFR

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other Chapter 18

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 1045	System Type	Sprinkler/Nozzle
	Density	- .001	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 100	( ) Dry	Model VK510
E	Elevation at Highest Outlet	- 17	( ) Deluge	Size 1"
S	Hose Allowance - Inside	- N/A	( ) Preaction	K-Factor 25.2
I	Rack Sprinkler Allowance	- N/A	( ) Other	Temp.Rat.165
G	Hose Allowance - Outside	- 250	HEAD SPEC FOR	ESFR

N Note

Calculation Flow Required - 1436 Press Required - 76  
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9-11-15		Cap. -
T	Time of Test - 9:00 AM	Rated Cap.-	Elev.-
E	Static Press - 84	@ Press -	
R	Residual Press - 80	Elev. -	Well
	Flow - 1403		Proof Flow
S	Elevation - 0		

U Location - ACROSS THE STREET FROM SITE ON CANCO ST.

P Source of Information - PORTLAND WATER DISTRICT

C	Commodity TIRES	Class	Location
O	Storage Ht. UP TO 25	Area	Aisle W.
M	Storage Method: Solid Piled 20 %	Palletized 80 %	Rack
M	(X) Single Row ( ) Conven. Pallet ( ) Auto. Storage ( ) Encap.		
S	(X) Double Row ( ) Slave Pallet ( ) Solid Shelf ( ) Non		
T	( ) Mult. Row ( ) Open Shelf		

R K Flue Spacing Clearance:Storage to Ceiling 36"  
 A Longitudinal Transverse

G Horizontal Barriers Provided:


# Water Supply Curve (C)

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 2  
Date 9-15-15

City Water Supply:  
C1 - Static Pressure : 84  
C2 - Residual Pressure: 80  
C2 - Residual Flow : 1403

Demand:  
D1 - Elevation : 10.394  
D2 - System Flow : 1185.86  
D2 - System Pressure : 75.487  
Hose ( Demand ) : 250  
D3 - System Demand : 1435.86  
Safety Margin : 4.338



# Fittings Used Summary

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 3  
Date 9-15-15

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 4  
Date 9-15-15

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
C1	14.8		21.36	na				
209	17.0		17.25	na				
210	17.0	25.2	15.24	na	98.37	0.001	100	15.0
211	17.0	25.2	15.0	na	97.6	0.001	100	15.0
212	17.0	25.2	15.0	na	97.6	0.001	100	15.0
213	17.0	25.2	15.96	na	100.66	0.001	100	15.0
214	17.0		21.84	na				
C3	14.8		21.46	na				
219	17.0		17.33	na				
220	17.0	25.2	15.29	na	98.55	0.001	100	15.0
221	17.0	25.2	15.05	na	97.77	0.001	100	15.0
222	17.0	25.2	15.05	na	97.77	0.001	100	15.0
223	17.0	25.2	16.0	na	100.8	0.001	100	15.0
224	17.0		21.87	na				
C5	14.8		21.75	na				
229	17.0		17.54	na				
230	17.0	25.2	15.45	na	99.05	0.001	100	15.0
231	17.0	25.2	15.2	na	98.24	0.001	100	15.0
232	17.0	25.2	15.2	na	98.24	0.001	100	15.0
233	17.0	25.2	16.12	na	101.19	0.001	100	15.0
234	17.0		21.94	na				
C7	14.8		22.54	na				
240	17.0		21.99	na				
241	17.0		23.53	na				
C9	14.8		23.18	na				
250	17.0		22.64	na				
251	17.0		24.24	na				
C11	14.8		23.61	na				
260	17.0		23.0	na				
261	17.0		24.33	na				
C20	14.8		24.12	na				
C21	23.5		20.96	na				
C2	14.8		24.7	na				
C4	14.8		24.73	na				
C6	14.8		24.79	na				
C8	14.8		24.93	na				
CA	14.8		25.39	na				
C10	14.8		25.42	na				
C12	14.8		25.47	na				
C30	14.8		25.59	na				
C31	23.5		21.96	na				
C32	23.5		22.23	na				
CB	14.8		25.81	na				
CC	22.0		23.14	na				
A1	22.0		23.83	na				
2	25.5		22.53	na				
6	25.5		22.76	na				
A3	22.0		23.89	na				
11	25.5		22.57	na				
15	25.5		22.78	na				
A5	22.0		24.01	na				
21	25.5		22.65	na				
25	25.5		22.82	na				
A7	22.0		24.13	na				
30	25.5		22.74	na				
31	25.5		22.88	na				
A9	22.0		24.22	na				
40	25.5		22.82	na				
41	25.5		22.95	na				
A11	22.0		24.26	na				
50	25.5		22.87	na				
51	25.5		23.0	na				

# Flow Summary - Standard

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 5  
Date 9-15-15

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
A13	22.0		24.29	na				
60	25.5		22.94	na				
61	25.5		23.11	na				
A15	22.0		24.31	na				
70	25.5		23.01	na				
71	25.5		23.24	na				
A17	22.0		24.32	na				
80	25.5		23.09	na				
81	25.5		23.41	na				
A19	22.0		24.34	na				
90	25.5		23.2	na				
91	25.5		23.61	na				
CD	22.0		23.82	na				
A2	22.0		24.4	na				
A4	22.0		24.41	na				
A6	22.0		24.42	na				
A8	22.0		24.47	na				
A10	22.0		24.53	na				
A12	22.0		24.59	na				
A14	22.0		24.72	na				
A16	22.0		24.87	na				
A18	22.0		25.09	na				
A22	22.0		25.24	na				
B1	24.0		21.8	na				
100	27.0		20.58	na				
105	27.0		20.71	na				
B3	24.0		21.82	na				
110	27.0		20.59	na				
115	27.0		20.71	na				
B5	24.0		21.85	na				
120	27.0		20.62	na				
125	27.0		20.72	na				
B7	24.0		21.88	na				
126	27.0		20.64	na				
127	27.0		20.74	na				
B9	24.0		21.9	na				
130	27.0		20.66	na				
131	27.0		20.76	na				
B11	24.0		21.93	na				
135	27.0		20.69	na				
136	27.0		20.79	na				
B13	24.0		21.95	na				
140	27.0		20.71	na				
141	27.0		20.82	na				
B15	24.0		21.96	na				
145	27.0		20.74	na				
146	27.0		20.87	na				
B17	24.0		21.98	na				
150	27.0		20.77	na				
151	27.0		20.93	na				
B19	24.0		21.98	na				
155	27.0		20.81	na				
156	27.0		21.01	na				
B21	24.0		21.99	na				
160	27.0		20.85	na				
161	27.0		21.11	na				
B23	24.0		22.1	na				
165	27.0		20.98	na				
166	27.0		21.28	na				
C22	24.0		21.8	na				
B2	24.0		22.05	na				
B4	24.0		22.05	na				

# Flow Summary - Standard

HIGH TECH FIRE PROTECTION  
 NOKIAN TYRES WALTON STREET GRID 3

Page 6  
 Date 9-15-15

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
B6	24.0		22.06	na				
B8	24.0		22.07	na				
B10	24.0		22.09	na				
B12	24.0		22.12	na				
B14	24.0		22.16	na				
B16	24.0		22.21	na				
B18	24.0		22.29	na				
B20	24.0		22.38	na				
B22	24.0		22.49	na				
C33	24.0		22.66	na				
B24	24.0		22.68	na				
C34	24.0		23.08	na				
C35	22.0		24.21	na				
A21	22.0		24.31	na				
A20	22.0		25.34	na				
TOR	22.0		27.67	na				
BOR	6.0		36.37	na				
BASE	0.0		45.98	na				
H1	0.0		63.38	na				
H2	0.0		65.02	na				
HOSE	0.0		68.99	na	250.0			
TEST	-7.0		75.49	na				

The maximum velocity is 15.46 and it occurs in the pipe between nodes HOSE and TEST

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 7  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
C1	-191.68	2.635	1X	14.827	1.500	21.355				
to		120.0	1T	16.474	31.301	-0.953				
209	-191.68	-0.0960		0.0	32.801	-3.148		Vel = 11.28		
209	0.0	2.635		0.0	21.000	17.254				
to		120.0		0.0	0.0	0.0				
210	-191.68	-0.0960		0.0	21.000	-2.016		Vel = 11.28		
210	98.37	2.635		0.0	9.400	15.238		K Factor = 25.20		
to		120.0		0.0	0.0	0.0				
211	-93.31	-0.0253		0.0	9.400	-0.238		Vel = 5.49		
211	97.60	2.635		0.0	8.000	15.000		K Factor = 25.20		
to		120.0		0.0	0.0	0.0				
212	4.29	0.0001		0.0	8.000	0.001		Vel = 0.25		
212	97.60	2.635	4V	23.613	8.400	15.001		K Factor = 25.20		
to		120.0		0.0	23.613	0.0				
213	101.89	0.0298		0.0	32.013	0.954		Vel = 5.99		
213	100.66	2.635	1X	14.827	40.500	15.955		K Factor = 25.20		
to		120.0		0.0	14.827	0.0				
214	202.55	0.1063		0.0	55.327	5.881		Vel = 11.92		
214	0.0	2.635	1T	16.474	1.500	21.836				
to		120.0		0.0	16.474	0.953				
C2	202.55	0.1063		0.0	17.974	1.911		Vel = 11.92		
	0.0									
	202.55					24.700		K Factor = 40.76		
C3	-192.61	2.635	1X	14.827	1.500	21.458				
to		120.0	1T	16.474	31.301	-0.953				
219	-192.61	-0.0969		0.0	32.801	-3.177		Vel = 11.33		
219	0.0	2.635		0.0	21.000	17.328				
to		120.0		0.0	0.0	0.0				
220	-192.61	-0.0969		0.0	21.000	-2.034		Vel = 11.33		
220	98.55	2.635		0.0	9.400	15.294		K Factor = 25.20		
to		120.0		0.0	0.0	0.0				
221	-94.06	-0.0256		0.0	9.400	-0.241		Vel = 5.53		
221	97.77	2.635		0.0	8.000	15.053		K Factor = 25.20		
to		120.0		0.0	0.0	0.0				
222	3.71	0.0		0.0	8.000	0.0		Vel = 0.22		
222	97.77	2.635	4V	23.613	8.400	15.053		K Factor = 25.20		
to		120.0		0.0	23.613	0.0				
223	101.48	0.0296		0.0	32.013	0.948		Vel = 5.97		
223	100.80	2.635	1X	14.827	40.500	16.001		K Factor = 25.20		
to		120.0		0.0	14.827	0.0				
224	202.28	0.1060		0.0	55.327	5.867		Vel = 11.90		
224	0.0	2.635	1T	16.474	1.500	21.868				
to		120.0		0.0	16.474	0.953				
C4	202.28	0.1060		0.0	17.974	1.906		Vel = 11.90		
	0.0									
	202.28					24.727		K Factor = 40.68		
C5	-195.33	2.635	1X	14.827	1.500	21.751				
to		120.0	1T	16.474	31.301	-0.953				
229	-195.33	-0.0994		0.0	32.801	-3.260		Vel = 11.49		



# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 8  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
229 to 230	0.0 -195.33	2.635 120.0 -0.0994		0.0 0.0 0.0	21.000 0.0 21.000	17.538 0.0 -2.087			Vel = 11.49	
230 to 231	99.05 -96.28	2.635 120.0 -0.0269		0.0 0.0 0.0	9.400 0.0 9.400	15.451 0.0 -0.253		K Factor = 25.20	Vel = 5.66	
231 to 232	98.24 1.96	2.635 120.0 0.0		0.0 0.0 0.0	8.000 0.0 8.000	15.198 0.0 0.0		K Factor = 25.20	Vel = 0.12	
232 to 233	98.24 100.2	2.635 120.0 0.0289	4V	23.613 0.0 0.0	8.400 23.613 32.013	15.198 0.0 0.926		K Factor = 25.20	Vel = 5.90	
233 to 234	101.20 201.4	2.635 120.0 0.1052	1X	14.827 0.0 0.0	40.500 14.827 55.327	16.124 0.0 5.819		K Factor = 25.20	Vel = 11.85	
234 to C6	0.0 201.4	2.635 120.0 0.1052	1T	16.474 0.0 0.0	1.500 16.474 17.974	21.943 0.953 1.891			Vel = 11.85	
	0.0 201.40					24.787		K Factor = 40.45		
C7 to 240	63.02 63.02	2.635 120.0 0.0123	1X 1T	14.827 16.474 0.0	1.500 31.301 32.801	22.540 -0.953 0.402			Vel = 3.71	
240 to 241	0.0 63.02	2.635 120.0 0.0123	4V 1X	23.613 14.827 0.0	87.000 38.440 125.440	21.989 0.0 1.538			Vel = 3.71	
241 to C2	0.0 63.02	2.635 120.0 0.0122	1T	16.474 0.0 0.0	1.500 16.474 17.974	23.527 0.953 0.220			Vel = 3.71	
	0.0 63.02					24.700		K Factor = 12.68		
C9 to 250	64.31 64.31	2.635 120.0 0.0127	1X 1T	14.827 16.474 0.0	1.500 31.301 32.801	23.176 -0.953 0.418			Vel = 3.78	
250 to 251	0.0 64.31	2.635 120.0 0.0127	4V 1X	23.613 14.827 0.0	87.000 38.440 125.440	22.641 0.0 1.597			Vel = 3.78	
251 to C10	0.0 64.31	2.635 120.0 0.0127	1T	16.474 0.0 0.0	1.500 16.474 17.974	24.238 0.953 0.228			Vel = 3.78	
	0.0 64.31					25.419		K Factor = 12.76		
C11 to 260	58.14 58.14	2.635 120.0 0.0105	1X 1T	14.827 16.474 0.0	1.500 31.301 32.801	23.607 -0.953 0.346			Vel = 3.42	
260 to 261	0.0 58.14	2.635 120.0 0.0106	4V 1X	23.613 14.827 0.0	87.000 38.440 125.440	23.000 0.0 1.325			Vel = 3.42	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 9  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
261 to C12	0.0 58.14	2.635 120.0 0.0106	1T	16.474 0.0 0.0	1.500 16.474 17.974	24.325 0.953 0.190		Vel =	3.42	
	0.0 58.14					25.468		K Factor =	11.52	
C1 to C3	191.68 191.68	4.26 120.0 0.0093		0.0 0.0 0.0	11.100 0.0 11.100	21.355 0.0 0.103		Vel =	4.31	
C3 to C5	192.62 384.3	4.26 120.0 0.0335		0.0 0.0 0.0	8.750 0.0 8.750	21.458 0.0 0.293		Vel =	8.65	
C5 to C7	195.33 579.63	4.26 120.0 0.0717		0.0 0.0 0.0	11.000 0.0 11.000	21.751 0.0 0.789		Vel =	13.05	
C7 to C9	-63.02 516.61	4.26 120.0 0.0578		0.0 0.0 0.0	11.000 0.0 11.000	22.540 0.0 0.636		Vel =	11.63	
C9 to C11	-64.31 452.3	4.26 120.0 0.0454		0.0 0.0 0.0	9.500 0.0 9.500	23.176 0.0 0.431		Vel =	10.18	
C11 to C20	-58.14 394.16	4.26 120.0 0.0351	1V	8.954 0.0 0.0	5.600 8.954 14.554	23.607 0.0 0.511		Vel =	8.87	
C20 to C21	0.0 394.16	4.26 120.0 0.0351	1V	8.954 0.0 0.0	8.500 8.954 17.454	24.118 -3.768 0.612		Vel =	8.87	
C21 to C22	0.0 394.16	4.26 120.0 0.0352	1X	21.067 0.0 0.0	9.000 21.067 30.067	20.962 -0.217 1.057		Vel =	8.87	
	0.0 394.16					21.802		K Factor =	84.42	
C2 to C4	265.57 265.57	6.357 120.0 0.0024		0.0 0.0 0.0	11.100 0.0 11.100	24.700 0.0 0.027		Vel =	2.68	
C4 to C6	202.28 467.85	6.357 120.0 0.0069		0.0 0.0 0.0	8.750 0.0 8.750	24.727 0.0 0.060		Vel =	4.73	
C6 to C8	201.40 669.25	6.357 120.0 0.0133		0.0 0.0 0.0	11.000 0.0 11.000	24.787 0.0 0.146		Vel =	6.77	
C8 to CA	0.0 669.25	6.357 120.0 0.0133	1X	31.433 0.0 0.0	2.750 31.433 34.183	24.933 0.0 0.455		Vel =	6.77	
CA to C10	-333.79 335.46	6.357 120.0 0.0037		0.0 0.0 0.0	8.400 0.0 8.400	25.388 0.0 0.031		Vel =	3.39	
C10 to C12	64.31 399.77	6.357 120.0 0.0052		0.0 0.0 0.0	9.500 0.0 9.500	25.419 0.0 0.049		Vel =	4.04	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 10  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
C12 to C30	58.14 457.91	6.357 120.0 0.0066	1V	12.573 0.0 0.0	5.600 12.573 18.173	25.468 0.0 0.120		Vel =	4.63	
C30 to C31	0.0 457.91	6.357 120.0 0.0066	1V	12.573 0.0 0.0	8.900 12.573 21.473	25.588 -3.768 0.142		Vel =	4.63	
C31 to C32	0.0 457.91	6.357 120.0 0.0066	1X	31.433 0.0 0.0	9.000 31.433 40.433	21.962 0.0 0.266		Vel =	4.63	
C32 to C33	73.25 531.16	6.357 120.0 0.0087	1X	31.433 0.0 0.0	43.000 31.433 74.433	22.228 -0.217 0.647		Vel =	5.37	
	0.0 531.16					22.658		K Factor =	111.59	
CA to CB	333.78 333.78	4.26 120.0 0.0258	1V	8.954 0.0 0.0	7.500 8.954 16.454	25.388 0.0 0.425		Vel =	7.51	
CB to CC	0.0 333.78	4.26 120.0 0.0258	1V	8.954 0.0 0.0	8.400 8.954 17.354	25.813 -3.118 0.447		Vel =	7.51	
CC to CD	0.0 333.78	4.26 120.0 0.0258	1X	21.067 0.0 0.0	5.300 21.067 26.367	23.142 0.0 0.681		Vel =	7.51	
	0.0 333.78					23.823		K Factor =	68.39	
A1 to 2	43.56 43.56	2.635 120.0 0.0062	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	23.827 -1.516 0.216		Vel =	2.56	
2 to 6	0.0 43.56	2.635 120.0 0.0062	1X	14.827 0.0 0.0	23.200 14.827 38.027	22.527 0.0 0.235		Vel =	2.56	
6 to A2	0.0 43.56	2.635 120.0 0.0062	1T	16.474 0.0 0.0	3.500 16.474 19.974	22.762 1.516 0.124		Vel =	2.56	
	0.0 43.56					24.402		K Factor =	8.82	
A3 to 11	41.31 41.31	2.635 120.0 0.0056	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	23.887 -1.516 0.195		Vel =	2.43	
11 to 15	0.0 41.31	2.635 120.0 0.0056	1X	14.827 0.0 0.0	23.200 14.827 38.027	22.566 0.0 0.214		Vel =	2.43	
15 to A4	0.0 41.31	2.635 120.0 0.0056	1T	16.474 0.0 0.0	3.500 16.474 19.974	22.780 1.516 0.112		Vel =	2.43	
	0.0 41.31					24.408		K Factor =	8.36	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 11  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
A5 to 21	36.46 36.46	2.635 120.0 0.0045	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.011 -1.516 0.155			Vel = 2.15	
21 to 25	0.0 36.46	2.635 120.0 0.0045	1X	14.827 0.0 0.0	23.200 14.827 38.027	22.650 0.0 0.170			Vel = 2.15	
25 to A6	0.0 36.46	2.635 120.0 0.0045	1T	16.474 0.0 0.0	3.500 16.474 19.974	22.820 1.516 0.089			Vel = 2.15	
	0.0 36.46					24.425			K Factor = 7.38	
A7 to 30	32.67 32.67	2.635 120.0 0.0036	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.129 -1.516 0.127			Vel = 1.92	
30 to 31	0.0 32.67	2.635 120.0 0.0036	1X	14.827 0.0 0.0	23.200 14.827 38.027	22.740 0.0 0.138			Vel = 1.92	
31 to A8	0.0 32.67	2.635 120.0 0.0036	1T	16.474 0.0 0.0	3.500 16.474 19.974	22.878 1.516 0.072			Vel = 1.92	
	0.0 32.67					24.466			K Factor = 6.60	
A9 to 40	31.53 31.53	2.635 120.0 0.0034	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.215 -1.516 0.119			Vel = 1.86	
40 to 41	0.0 31.53	2.635 120.0 0.0034	1X	14.827 0.0 0.0	23.200 14.827 38.027	22.818 0.0 0.129			Vel = 1.86	
41 to A10	0.0 31.53	2.635 120.0 0.0034	1T	16.474 0.0 0.0	3.500 16.474 19.974	22.947 1.516 0.068			Vel = 1.86	
	0.0 31.53					24.531			K Factor = 6.37	
A11 to 50	32.63 32.63	2.635 120.0 0.0036	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.255 -1.516 0.127			Vel = 1.92	
50 to 51	0.0 32.63	2.635 120.0 0.0036	1X	14.827 0.0 0.0	23.200 14.827 38.027	22.866 0.0 0.138			Vel = 1.92	
51 to A12	0.0 32.63	2.635 120.0 0.0036	1T	16.474 0.0 0.0	3.500 16.474 19.974	23.004 1.516 0.072			Vel = 1.92	
	0.0 32.63					24.592			K Factor = 6.58	
A13 to 60	36.87 36.87	2.635 120.0 0.0045	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.294 -1.516 0.158			Vel = 2.17	
60 to 61	0.0 36.87	2.635 120.0 0.0045	1X	14.827 0.0 0.0	23.200 14.827 38.027	22.936 0.0 0.173			Vel = 2.17	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 12  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
61 to A14	0.0 36.87	2.635 120.0 0.0046	1T	16.474 0.0 0.0	3.500 16.474 19.974	23.109 1.516 0.091		Vel = 2.17		
	0.0 36.87					24.716		K Factor = 7.42		
A15 to 70	43.01 43.01	2.635 120.0 0.0061	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.311 -1.516 0.211		Vel = 2.53		
70 to 71	0.0 43.01	2.635 120.0 0.0060	1X	14.827 0.0 0.0	23.200 14.827 38.027	23.006 0.0 0.230		Vel = 2.53		
71 to A16	0.0 43.01	2.635 120.0 0.0060	1T	16.474 0.0 0.0	3.500 16.474 19.974	23.236 1.516 0.120		Vel = 2.53		
	0.0 43.01					24.872		K Factor = 8.62		
A17 to 80	51.27 51.27	2.635 120.0 0.0084	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.316 -1.516 0.291		Vel = 3.02		
80 to 81	0.0 51.27	2.635 120.0 0.0084	1X	14.827 0.0 0.0	23.200 14.827 38.027	23.091 0.0 0.318		Vel = 3.02		
81 to A18	0.0 51.27	2.635 120.0 0.0084	1T	16.474 0.0 0.0	3.500 16.474 19.974	23.409 1.516 0.167		Vel = 3.02		
	0.0 51.27					25.092		K Factor = 10.24		
A19 to 90	58.66 58.66	2.635 120.0 0.0107	1X 1T	14.827 16.474 0.0	3.500 31.301 34.801	24.343 -1.516 0.374		Vel = 3.45		
90 to 91	0.0 58.66	2.635 120.0 0.0108	1X	14.827 0.0 0.0	23.200 14.827 38.027	23.201 0.0 0.409		Vel = 3.45		
91 to A20	0.0 58.66	2.635 120.0 0.0107	1T	16.474 0.0 0.0	3.500 16.474 19.974	23.610 1.516 0.214		Vel = 3.45		
	0.0 58.66					25.340		K Factor = 11.65		
A1 to CD	-43.56 -43.56	4.26 120.0 -0.0006		0.0 0.0 0.0	6.750 0.0 6.750	23.827 0.0 -0.004		Vel = 0.98		
CD to A3	333.78 290.22	4.26 120.0 0.0200		0.0 0.0 0.0	3.200 0.0 3.200	23.823 0.0 0.064		Vel = 6.53		
A3 to A5	-41.31 248.91	4.26 120.0 0.0149		0.0 0.0 0.0	8.300 0.0 8.300	23.887 0.0 0.124		Vel = 5.60		

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 13  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
A5 to A7	-36.46 212.45	4.26 120.0 0.0112		0.0 0.0 0.0	10.500 0.0 10.500	24.011 0.0 0.118			Vel = 4.78	
A7 to A9	-32.67 179.78	4.26 120.0 0.0082		0.0 0.0 0.0	10.500 0.0 10.500	24.129 0.0 0.086			Vel = 4.05	
A9 to A11	-31.53 148.25	4.26 120.0 0.0057		0.0 0.0 0.0	7.000 0.0 7.000	24.215 0.0 0.040			Vel = 3.34	
A11 to A13	-32.64 115.61	4.26 120.0 0.0037		0.0 0.0 0.0	10.500 0.0 10.500	24.255 0.0 0.039			Vel = 2.60	
A13 to A15	-36.87 78.74	4.26 120.0 0.0017		0.0 0.0 0.0	10.000 0.0 10.000	24.294 0.0 0.017			Vel = 1.77	
A15 to A17	-43.00 35.74	4.26 120.0 0.0005		0.0 0.0 0.0	10.500 0.0 10.500	24.311 0.0 0.005			Vel = 0.80	
A17 to A21	-51.27 -15.53	4.26 120.0 -0.0001	1X	21.067 0.0 0.0	5.400 21.067 26.467	24.316 0.0 -0.003			Vel = 0.35	
	0.0 -15.53					24.313			K Factor = -3.15	
A19 to A21	-58.66 -58.66	4.26 120.0 -0.0010	1T	26.334 0.0 0.0	2.750 26.334 29.084	24.343 0.0 -0.030			Vel = 1.32	
	0.0 -58.66					24.313			K Factor = -11.90	
A2 to A4	43.56 43.56	4.26 120.0 0.0006		0.0 0.0 0.0	9.900 0.0 9.900	24.402 0.0 0.006			Vel = 0.98	
A4 to A6	41.31 84.87	4.26 120.0 0.0020		0.0 0.0 0.0	8.300 0.0 8.300	24.408 0.0 0.017			Vel = 1.91	
A6 to A8	36.46 121.33	4.26 120.0 0.0039		0.0 0.0 0.0	10.500 0.0 10.500	24.425 0.0 0.041			Vel = 2.73	
A8 to A10	32.67 154.0	4.26 120.0 0.0062		0.0 0.0 0.0	10.500 0.0 10.500	24.466 0.0 0.065			Vel = 3.47	
A10 to A12	31.54 185.54	4.26 120.0 0.0087		0.0 0.0 0.0	7.000 0.0 7.000	24.531 0.0 0.061			Vel = 4.18	
A12 to A14	32.63 218.17	4.26 120.0 0.0118		0.0 0.0 0.0	10.500 0.0 10.500	24.592 0.0 0.124			Vel = 4.91	
A14 to A16	36.87 255.04	4.26 120.0 0.0156		0.0 0.0 0.0	10.000 0.0 10.000	24.716 0.0 0.156			Vel = 5.74	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 14  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
A16 to A18	43.01 298.05	4.26 120.0 0.0210		0.0 0.0 0.0	10.500 0.0 10.500	24.872 0.0 0.220			Vel = 6.71	
A18 to A22	51.26 349.31	4.26 120.0 0.0281		0.0 0.0 0.0	5.400 0.0 5.400	25.092 0.0 0.152			Vel = 7.86	
A22 to A20	777.88 1127.19	6.357 120.0 0.0349		0.0 0.0 0.0	2.750 0.0 2.750	25.244 0.0 0.096			Vel = 11.39	
	0.0 1127.19					25.340			K Factor = 223.92	
B1 to 100	24.91 24.91	2.635 120.0 0.0022	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.802 -1.299 0.075			Vel = 1.47	
100 to 105	0.0 24.91	2.635 120.0 0.0022	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.578 0.0 0.127			Vel = 1.47	
105 to B2	0.0 24.91	2.635 120.0 0.0022	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.705 1.299 0.043			Vel = 1.47	
	0.0 24.91					22.047			K Factor = 5.31	
B3 to 110	24.22 24.22	2.635 120.0 0.0021	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.816 -1.299 0.071			Vel = 1.42	
110 to 115	0.0 24.22	2.635 120.0 0.0021	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.588 0.0 0.121			Vel = 1.42	
115 to B4	0.0 24.22	2.635 120.0 0.0021	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.709 1.299 0.041			Vel = 1.42	
	0.0 24.22					22.049			K Factor = 5.16	
B5 to 120	22.47 22.47	2.635 120.0 0.0018	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.853 -1.299 0.062			Vel = 1.32	
120 to 125	0.0 22.47	2.635 120.0 0.0018	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.616 0.0 0.106			Vel = 1.32	
125 to B6	0.0 22.47	2.635 120.0 0.0018	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.722 1.299 0.035			Vel = 1.32	
	0.0 22.47					22.056			K Factor = 4.78	
B7 to 126	21.55 21.55	2.635 120.0 0.0017	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.880 -1.299 0.057			Vel = 1.27	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 15  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
126 to 127	0.0 21.55	2.635 120.0 0.0017	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.638 0.0 0.097		Vel = 1.27		
127 to B8	0.0 21.55	2.635 120.0 0.0017	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.735 1.299 0.034		Vel = 1.27		
	0.0 21.55					22.068		K Factor = 4.59		
B9 to 130	21.25 21.25	2.635 120.0 0.0016	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.904 -1.299 0.056		Vel = 1.25		
130 to 131	0.0 21.25	2.635 120.0 0.0016	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.661 0.0 0.095		Vel = 1.25		
131 to B10	0.0 21.25	2.635 120.0 0.0016	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.756 1.299 0.032		Vel = 1.25		
	0.0 21.25					22.087		K Factor = 4.52		
B11 to 135	21.81 21.81	2.635 120.0 0.0017	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.930 -1.299 0.059		Vel = 1.28		
135 to 136	0.0 21.81	2.635 120.0 0.0017	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.690 0.0 0.099		Vel = 1.28		
136 to B12	0.0 21.81	2.635 120.0 0.0017	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.789 1.299 0.034		Vel = 1.28		
	0.0 21.81					22.122		K Factor = 4.64		
B13 to 140	22.92 22.92	2.635 120.0 0.0019	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.946 -1.299 0.064		Vel = 1.35		
140 to 141	0.0 22.92	2.635 120.0 0.0019	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.711 0.0 0.110		Vel = 1.35		
141 to B14	0.0 22.92	2.635 120.0 0.0019	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.821 1.299 0.037		Vel = 1.35		
	0.0 22.92					22.157		K Factor = 4.87		
B15 to 145	25.02 25.02	2.635 120.0 0.0022	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.961 -1.299 0.076		Vel = 1.47		
145 to 146	0.0 25.02	2.635 120.0 0.0022	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.738 0.0 0.129		Vel = 1.47		
146 to B16	0.0 25.02	2.635 120.0 0.0022	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.867 1.299 0.043		Vel = 1.47		



# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 16  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 25.02						22.209		K Factor = 5.31	
B17 to 150	28.30 28.3	2.635 120.0 0.0028	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.975 -1.299 0.096			Vel = 1.67	
150 to 151	0.0 28.3	2.635 120.0 0.0028	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.772 0.0 0.161			Vel = 1.67	
151 to B18	0.0 28.3	2.635 120.0 0.0028	1T	16.474 0.0 0.0	3.000 16.474 19.474	20.933 1.299 0.054			Vel = 1.67	
	0.0 28.30						22.286		K Factor = 5.99	
B19 to 155	32.07 32.07	2.635 120.0 0.0035	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.985 -1.299 0.120			Vel = 1.89	
155 to 156	0.0 32.07	2.635 120.0 0.0035	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.806 0.0 0.203			Vel = 1.89	
156 to B20	0.0 32.07	2.635 120.0 0.0035	1T	16.474 0.0 0.0	3.000 16.474 19.474	21.009 1.299 0.069			Vel = 1.89	
	0.0 32.07						22.377		K Factor = 6.78	
B21 to 160	36.63 36.63	2.635 120.0 0.0045	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	21.992 -1.299 0.153			Vel = 2.16	
160 to 161	0.0 36.63	2.635 120.0 0.0045	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.846 0.0 0.260			Vel = 2.16	
161 to B22	0.0 36.63	2.635 120.0 0.0045	1T	16.474 0.0 0.0	3.000 16.474 19.474	21.106 1.299 0.088			Vel = 2.16	
	0.0 36.63						22.493		K Factor = 7.72	
B23 to 165	39.76 39.76	2.635 120.0 0.0052	1X 1T	14.827 16.474 0.0	3.000 31.301 34.301	22.097 -1.299 0.179			Vel = 2.34	
165 to 166	0.0 39.76	2.635 120.0 0.0052	1X	14.827 0.0 0.0	43.000 14.827 57.827	20.977 0.0 0.302			Vel = 2.34	
166 to B24	0.0 39.76	2.635 120.0 0.0052	1T	16.474 0.0 0.0	3.000 16.474 19.474	21.279 1.299 0.102			Vel = 2.34	
	0.0 39.76						22.680		K Factor = 8.35	
B1 to C22	-24.91 -24.91	6.357 120.0 0.0		0.0 0.0 0.0	4.900 0.0 4.900	21.802 0.0 0.0			Vel = 0.25	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 17  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
C22	394.16	6.357		0.0	3.200	21.802				
to		120.0		0.0	0.0	0.0				
B3	369.25	0.0044		0.0	3.200	0.014		Vel =	3.73	
B3	-24.22	6.357		0.0	9.600	21.816				
to		120.0		0.0	0.0	0.0				
B5	345.03	0.0039		0.0	9.600	0.037		Vel =	3.49	
B5	-22.47	6.357		0.0	7.600	21.853				
to		120.0		0.0	0.0	0.0				
B7	322.56	0.0036		0.0	7.600	0.027		Vel =	3.26	
B7	-21.55	6.357		0.0	8.000	21.880				
to		120.0		0.0	0.0	0.0				
B9	301.01	0.0030		0.0	8.000	0.024		Vel =	3.04	
B9	-21.26	6.357		0.0	9.900	21.904				
to		120.0		0.0	0.0	0.0				
B11	279.75	0.0026		0.0	9.900	0.026		Vel =	2.83	
B11	-21.81	6.357		0.0	7.000	21.930				
to		120.0		0.0	0.0	0.0				
B13	257.94	0.0023		0.0	7.000	0.016		Vel =	2.61	
B13	-22.92	6.357		0.0	8.000	21.946				
to		120.0		0.0	0.0	0.0				
B15	235.02	0.0019		0.0	8.000	0.015		Vel =	2.38	
B15	-25.02	6.357		0.0	9.000	21.961				
to		120.0		0.0	0.0	0.0				
B17	210.0	0.0016		0.0	9.000	0.014		Vel =	2.12	
B17	-28.30	6.357		0.0	8.100	21.975				
to		120.0		0.0	0.0	0.0				
B19	181.7	0.0012		0.0	8.100	0.010		Vel =	1.84	
B19	-32.07	6.357		0.0	8.000	21.985				
to		120.0		0.0	0.0	0.0				
B21	149.63	0.0009		0.0	8.000	0.007		Vel =	1.51	
B21	-36.63	6.357	1X	31.433	8.750	21.992				
to		120.0		0.0	31.433	0.217				
C32	113.0	0.0005		0.0	40.183	0.019		Vel =	1.14	
	0.0									
	113.00					22.228		K Factor =	23.97	
B23	-39.76	2.635	1X	14.827	1.500	22.097				
to		120.0		0.0	14.827	0.217				
C32	-39.76	-0.0053		0.0	16.327	-0.086		Vel =	2.34	
	0.0									
	-39.76					22.228		K Factor =	-8.43	
B2	24.91	4.26		0.0	8.000	22.047				
to		120.0		0.0	0.0	0.0				
B4	24.91	0.0002		0.0	8.000	0.002		Vel =	0.56	
B4	24.22	4.26		0.0	9.600	22.049				
to		120.0		0.0	0.0	0.0				
B6	49.13	0.0007		0.0	9.600	0.007		Vel =	1.11	
B6	22.47	4.26		0.0	7.500	22.056				
to		120.0		0.0	0.0	0.0				
B8	71.6	0.0016		0.0	7.500	0.012		Vel =	1.61	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 18  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
B8	21.55	4.26		0.0	8.000	22.068				
to		120.0		0.0	0.0	0.0				
B10	93.15	0.0024		0.0	8.000	0.019		Vel =	2.10	
B10	21.26	4.26		0.0	9.900	22.087				
to		120.0		0.0	0.0	0.0				
B12	114.41	0.0035		0.0	9.900	0.035		Vel =	2.58	
B12	21.81	4.26		0.0	7.000	22.122				
to		120.0		0.0	0.0	0.0				
B14	136.22	0.0050		0.0	7.000	0.035		Vel =	3.07	
B14	22.92	4.26		0.0	8.000	22.157				
to		120.0		0.0	0.0	0.0				
B16	159.14	0.0065		0.0	8.000	0.052		Vel =	3.58	
B16	25.02	4.26		0.0	9.000	22.209				
to		120.0		0.0	0.0	0.0				
B18	184.16	0.0086		0.0	9.000	0.077		Vel =	4.15	
B18	28.30	4.26		0.0	8.100	22.286				
to		120.0		0.0	0.0	0.0				
B20	212.46	0.0112		0.0	8.100	0.091		Vel =	4.78	
B20	32.07	4.26		0.0	8.000	22.377				
to		120.0		0.0	0.0	0.0				
B22	244.53	0.0145		0.0	8.000	0.116		Vel =	5.50	
B22	36.63	4.26		0.0	8.750	22.493				
to		120.0		0.0	0.0	0.0				
C33	281.16	0.0189		0.0	8.750	0.165		Vel =	6.33	
C33	531.16	6.357		0.0	1.200	22.658				
to		120.0		0.0	0.0	0.0				
B24	812.32	0.0183		0.0	1.200	0.022		Vel =	8.21	
B24	39.75	6.357	1V	12.573	6.500	22.680				
to		120.0		0.0	12.573	0.0				
C34	852.07	0.0208		0.0	19.073	0.397		Vel =	8.61	
C34	0.0	6.357	1V	12.573	0.100	23.077				
to		120.0		0.0	12.573	0.866				
C35	852.07	0.0208		0.0	12.673	0.264		Vel =	8.61	
C35	0.0	6.357		0.0	5.100	24.207				
to		120.0		0.0	0.0	0.0				
A21	852.07	0.0208		0.0	5.100	0.106		Vel =	8.61	
A21	-74.19	6.357	1X	31.433	21.500	24.313				
to		120.0		0.0	31.433	0.0				
A22	777.88	0.0176		0.0	52.933	0.931		Vel =	7.86	
	0.0									
	777.88					25.244		K Factor =	154.82	
A20	1185.86	6.357	1V	12.573	16.800	25.340				
to		120.0	1X	31.433	44.006	0.0				
TOR	1185.86	0.0384		0.0	60.806	2.332		Vel =	11.99	
TOR	0.0	6.065	1Fsp	0.0	16.000	27.672				
to		120.0		0.0	0.0	7.930		* Fixed loss =	1	
BOR	1185.86	0.0482		0.0	16.000	0.771		Vel =	13.17	
BOR	0.0	6.357	1Zia	0.0	2.000	36.373				
to		120.0		0.0	0.0	9.531		* Fixed loss =	6.933	
BASE	1185.86	0.0385		0.0	2.000	0.077		Vel =	11.99	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
NOKIAN TYRES WALTON STREET GRID 3

Page 19  
Date 9-15-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BASE to H1	0.0 1185.86	6.16 140.0 0.0336	1G 4.304 2E 40.168 1T 43.037	430.000 87.509 517.509	45.981 0.0 17.395		Vel = 12.77		
H1 to H2	0.0 1185.86	8.27 140.0 0.0080	1T 55.354 0.0 0.0	150.000 55.354 205.354	63.376 0.0 1.644		Vel = 7.08		
H2 to HOSE	0.0 1185.86	8.27 140.0 0.0080	1T 55.354 0.0 0.0	440.000 55.354 495.354	65.020 0.0 3.967		Vel = 7.08		
HOSE to TEST	250.00 1435.86	6.16 140.0 0.0479	1G 4.304 1E 20.084 1T 43.037	5.000 67.425 72.425	68.987 3.032 3.468		Qa = 250 Vel = 15.46		
	0.0 1435.86				75.487		K Factor = 165.26		