




APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,

11 June 96

FILL IN AND SIGN WITH INK

960527



To the INSPECTOR OF BUILDINGS, PORTLAND, ME. The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 1006 Forest Ave Use of Building Prof Office No. Stories New Building Existing "
Name and address of owner of appliance Dr. B. Cohen 04103
Installer's name and address Giroux Oil Service 343 Warren Ave Pltd Telephone 797-7111

To install Two Oil Fired-forced hot water heating systems
General Description of Work

IF HEATER, OR POWER BOILER

Location of appliance 1st fl rear Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? #2 oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 18"
From top of smoke pipe 18" From front of appliance 5' From sides or back of appliance 18"
Size of chimney flue 8" Other connections to same flue no
If gas fired, how vented? Rated maximum demand per hour 85,000 each
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner Beckett Labelled by underwriters' laboratories? Yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner cement Size of vent pipe 1 1/2"
Location of oil storage boiler room Number and capacity of tanks 2-275
Low water shut off Yes Make McDonald Miller No. 170
Will all tanks be more than five feet from any flame? no How many tanks enclosed? 2
Total capacity of any existing storage tanks for furnace burners none existing/willbe 2 @ 275

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Systems to be installed - Building permit for boiler room to be pulled.
Systems not to be activated until all permits pulled and approved.
Ron Giroux - Master Oil Burner 204 Cost of Work 1000.00
Amount of fee enclosed?

APPROVED:

Signature of Installer (Handwritten signature)

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY

Will there be in charge of the above person competent to see that the State and City requirements hereof observed? yes
Permit fee \$100.00
1. Burner & Logset
2. Remote control
3. High limit switch
4. Main cut-off switch
5. High water cut-off
6. High water supply line
7. Pressure on tanks & support
8. Oil tank venting
9. Oil tank venting
10. Oil tank venting
11. Oil tank venting
12. Oil tank venting
13. Oil tank venting
14. Oil tank venting
15. Oil tank venting
16. Oil tank venting
17. Oil tank venting
18. Oil tank venting
19. Oil tank venting
20. Oil tank venting

1. 1 1/2" FILL PIPE
2. 1 1/4" VENT PIPE
3. Kind of hose
4. Summer rigidity & support
5. Name & Label
6. Remote control
7. High limit control
8. Main cutoff switch
9. Low water cutoff
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Oil gauge
16. Instruction card
17. Oil leaks
18. Adequate ventilar
19. Smokepipe to c
20. Thermal cont