

143-A-034

Angus S. King  
Governor



Maine Department of Public Safety  
State Fire Marshal's Office  
164 State House Station  
Augusta, Maine 04333-0164



Michael F. Kelly  
Commissioner  
Chief John C. Dean  
State Fire Marshal  
Fax 207-624-8767

Phone 207-624-8744

Statement of Deficiencies and Plan of Corrections

Facility Name: Jennifer & Dennis Swan Location: 24 Elmwood Street Portland, ME 04103 Facility Type CBH Telephone : 207-797-2274 Resource ID : 374901 (FILE#: 63353)	Owner Name: Same Address: Same Same <div style="text-align: right; font-family: cursive; font-size: 2em;">area 3</div>
--	---

<p>During an inspection of your facility a certified State Inspector has found the following violations.</p>	<p>In this right hand column you are required to indicate how and when you will have these violations corrected. Complete this information and return this "Plan of Correction" to the above address within 10 days of receipt of this statement.</p>
--	---

1. 3-unit apartment house without interconnected AC detectors.
2. Hall doors are not fire rated.
3. Over fused box 30 AMP in 15 AMP.
4. **dc10** All floor levels of residence must have a smoke detector that is powered by the house electrical supply. This also includes the basement or usable crawl space. (NFPA 72)
5. **dc08** Smoke detectors must be located outside of the sleeping rooms and must be audible in the sleeping room while the doors are closed. (21-3.3.1)

WR:led

(PENDING)

cc: DHS

~~cc: Portland Fire Department~~

Date of Inspection: January 5, 2000

Inspector: William Romano

Date Sent : 3 April, 2000

Owner/Occupant Signature

Date: