

6/19/03 Footing/Back wall

Will use 5' ladders for tubes w/ fasteners & vertical spacing

6/19/03 Framing - OK

① Guard 35" on stairs

② No graspable rail

③ 1" step from deck to stairs

④ No nosing on stairs.

Called owner re: guard height

7/15/03 Handrail missing, will call when installed
jml/gz

8/19/03 handrails install, close out job