CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/20/16

NOTE: There is no Garage door Header, only 2x4 Plates and there is no Room for a garage door operator as the door TRACK is Just below the Collar ties, Also See picture in Demo Permit application

NOTE: This design Adds A over the garage door and Allows us t install a garage door operator, a well as supports the Rigde

offset ridge for reference only. not for construction as per applicant

EXISTING GARAGE

SCALE = 1/4" = 1'-0"

NEW GARAGE PLAN

Garage Height Existing & NEW
23 St. Joseph St.
Permit Application # 201602604