

**EST3 Addressable Fire Alarm System
Coleman Hall
University of New England
Portland, Maine**

System Narrative

In the event of an alarm from an actuated device, the following shall

occur: (Devices reporting an alarm: Manual Station, Smoke, Duct, or Water Flow)

- 1) Notify Portland Fire Department via AES Radio Box.
Notify Campus Security via Digital Communicator (DACT) and Central Station
- 2) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.
- 3) Sound a Code 3 Temporal on all Horn Circuits
- 4) Flash all strobe appliance circuits in a synchronized manner
- 5) Activate exterior red beacon

In the event of a supervisory condition from an actuated device, the following shall occur: (Devices reporting an Supervisory: Sprinkler Tamper Switch)

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.
- 2) Notify Campus Security via Digital Communicator (DACT) and Central Station

In the event of a system trouble report, the following shall occur:

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.
- 2) Notify Campus Security via Digital Communicator (DACT) and Central Station