Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/04/15

EST3 Addressable Fire Alarm System
Coleman Hall
University of New England
Portland, Maine

System Narrative

In the event of an alarm from an actuated device, the following shall occur: (Devices reporting an alarm: Manual Station, Smoke, Duct, or Water Flow)

1) Notify Portland Fire Department via AES Radio Box.
Notify Campus Security via Digital Communicator (DACT) and Central Station

2) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.

3) Sound a Code 3 Temporal on all Horn Circuits

4) Flash all strobe appliance circuits in a synchronized manner

5) Activate exterior red beacon

In the event of a supervisory condition from an actuated device, the following shall occur: (Devices reporting an Supervisory: Sprinkler Tamper Switch)

1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.

2) Notify Campus Security via Digital Communicator (DACT) and Central Station

In the event of a system trouble report, the following shall occur:

1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.

2) Notify Campus Security via Digital Communicator (DACT) and Central Station